

Installation Instructions

LP Conversion Kit

Foundation™ Packaged Rooftop Units 3 to 5 Tons

Model Number: BAYLPKT320*
Used With: GB*036-060
GD*036-060

SAFETY WARNING

Only qualified personnel should install and service the equipment. The installation, starting up, and servicing of heating, ventilating, and air-conditioning equipment can be hazardous and requires specific knowledge and training. Improperly installed, adjusted or altered equipment by an unqualified person could result in death or serious injury. When working on the equipment, observe all precautions in the literature and on the tags, stickers, and labels that are attached to the equipment.

August 2024

ACC-SVN188D-EN

©2024

1 Warnings, Cautions, and Notices

Read this manual thoroughly before operating or servicing this unit. Safety advisories appear throughout this manual as required. Your personal safety and the proper operation of this machine depend upon the strict observance of these precautions.

The three types of advisories are defined as follows:

WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.

CAUTION

Indicates a potentially hazardous situation which, if not avoided, could result in minor or moderate injury. It could also be used to alert against unsafe practices.

NOTICE

Indicates a situation that could result in equipment or property-damage only accidents.

Important Environmental Concerns

Scientific research has shown that certain man-made chemicals can affect the earth's naturally occurring stratospheric ozone layer when released to the atmosphere. In particular, several of the identified chemicals that may affect the ozone layer are refrigerants that contain Chlorine, Fluorine and Carbon (CFCs) and those containing Hydrogen, Chlorine, Fluorine and Carbon (HCFCs). Not all refrigerants containing these compounds have the same potential impact to the environment. Trane advocates the responsible handling of all refrigerants.

Important Responsible Refrigerant Practices

Trane believes that responsible refrigerant practices are important to the environment, our customers, and the air conditioning industry. All technicians who handle refrigerants must be certified according to local rules. For the USA, the Federal Clean Air Act (Section 608) sets forth the requirements for handling, reclaiming, recovering and recycling of certain refrigerants and the equipment that is used in these service procedures. In addition, some states or municipalities may have additional requirements that must also be adhered to for responsible management of refrigerants. Know the applicable laws and follow them.

2

WARNING

Proper Field Wiring and Grounding Required!

Failure to follow code could result in death or serious injury. All field wiring MUST be performed by qualified personnel. Improperly installed and grounded field wiring poses FIRE and ELECTROCUTION hazards. To avoid these hazards, you MUST follow requirements for field wiring installation and grounding as described in NEC and your local/state/national electrical codes.

WARNING

Personal Protective Equipment (PPE) Required!

Failure to wear proper PPE for the job being undertaken could result in death or serious injury. Technicians, in order to protect themselves from potential electrical, mechanical, and chemical hazards, MUST follow precautions in this manual and on the tags, stickers, and labels, as well as the instructions below:

- Before installing/servicing this unit, technicians MUST put on all PPE required for the work being undertaken (Examples; cut resistant gloves/sleeves, butyl gloves, safety glasses, hard hat/bump cap, fall protection, electrical PPE and arc flash clothing). ALWAYS refer to appropriate Safety Data Sheets (SDS) and OSHA guidelines for proper PPE.
- When working with or around hazardous chemicals, ALWAYS refer to the appropriate SDS and OSHA/GHS (Global Harmonized System of Classification and Labeling of Chemicals) guidelines for information on allowable personal exposure levels, proper respiratory protection and handling instructions.
- If there is a risk of energized electrical contact, arc, or flash, technicians MUST put on all PPE in accordance with OSHA, NFPA 70E, or other country-specific requirements for arc flash protection, PRIOR to servicing the unit. NEVER PERFORM ANY SWITCHING, DISCONNECTING, OR VOLTAGE TESTING WITHOUT PROPER ELECTRICAL PPE AND ARC FLASH CLOTHING. ENSURE ELECTRICAL METERS AND EQUIPMENT ARE PROPERLY RATED FOR INTENDED VOLTAGE.

3

WARNING

Follow EHS Policies!

Failure to follow instructions below could result in death or serious injury.

- All Trane personnel must follow the company's Environmental, Health and Safety (EHS) policies when performing work such as hot work, electrical, fall protection, lockout/tagout, refrigerant handling, etc. Where local regulations are more stringent than these policies, those regulations supersede these policies.
- Non-Trane personnel should always follow local regulations.

WARNING

R-454B Flammable A2L Refrigerant!

Failure to use proper equipment or components as described below could result in equipment failure, and possibly fire, which could result in death, serious injury, or equipment damage.

The equipment described in this manual uses R-454B refrigerant which is flammable (A2L). Use ONLY R-454B rated service equipment and components. For specific handling concerns with R-454B, contact your local representative.

Copyright

This document and the information in it are the property of Trane, and may not be used or reproduced in whole or in part without written permission. Trane reserves the right to revise this publication at any time, and to make changes to its content without obligation to notify any person of such revision or change.

Trademarks

All trademarks referenced in this document are the trademarks of their respective owners.

General Information

These instructions describe converting gas package unit models from natural gas to LP gas.

Important: Conversion from natural gas to LP gas is a critical procedure. Follow instructions closely.

Inspection

1. Check carefully for shipping damage. If any damage is found, report it immediately, and file a claim against the transportation company. Replace damaged parts with authorized parts only.
2. Compare the order number on the shipping label with the accessory identification information on the ordering and shipping documents to verify that the correct accessory has been received.

Table 1. Parts list BAYLPKT320*

Qty	Description
3	Orifice Spuds, Drill # 49 - 0.073 in.
2	Orifice Spuds, Drill # 50 - 0.070 in. Dia.
3	Orifice Spuds, Drill # 51 - 0.067 in. Dia.

Table 2. Orifice size selection

Unit	Gas heat input rating (MBH)	LP Orifice size	Air Orifice Plate (Part No. last 4 digits)
GB*036A(3,4)E(L or X) GD*036A(3,4,W)E(L or X)	72	#50	NA
GB*036A(3,4)E(M or Y) GD*036A(3,4,W,K)E(M or Y)	100	#51	NA
GB*048A(3,4)E(L or X) GD*048A(3,4,W)E(L or X)	72	#50	NA
GB*048A(3,4)E(M or Y) GD*048A(3,4,W)E(M or Y)	115	#49	NA

Table 2. Orifice size selection (continued)

Unit	Gas heat input rating (MBH)	LP Orifice size	Air Orifice Plate (Part No. last 4 digits)
GB*060A(3,4)E(L or X) GD*060A(3,4,W)E(L or X)	72	#50	NA
GB*060A(3,4)E(M or Y) GD*060A(3,4,W)E(M or Y)	115	#49	NA

Installation

Conversion Procedure

Note: Conversion should be made prior to installation of equipment at the job site.

1. Place the thermostat selector switch to the OFF position.


⚠ WARNING

Hazardous Voltage w/Capacitors and Gas!

Turn off the gas supply and disconnect all electric power, including remote disconnects before servicing unit. Follow proper lockout/tagout procedures to ensure the power can not be inadvertently energized. For variable frequency drives or other energy storing components provided by Trane or others, refer to the appropriate manufacturer's literature for allowable waiting periods for discharge of capacitors. Verify with an appropriate voltmeter that all capacitors have discharged. Failure to turn off gas or disconnect power before servicing could result in an explosion or electrocution which could result in death or serious injury.


2. Open the unit electrical disconnect switch.
3. Shut off gas supply to the unit.
4. Remove outdoor access panel and gas heat OD cover.
5. Break pipe union.
6. Disconnect pipe from gas valve.
7. Remove six screws from manifold bracket and valve support. See [Figure 1](#).

Figure 1. Remove screws from manifold bracket



8. Remove natural gas orifices from manifold. See [Figure 2](#).
9. Install LP orifices specified in [Table 2](#). Engage threads of manifold and tighten orifice three and one half turns.

Figure 2. Remove gas orifices



10. Install LP gas valve spring. Follow instructions provided with the conversion spring kit.
11. Reverse the disassembly procedure and secure all components in their respective position.
12. Attach the nameplate and label supplied with the conversion kit below the unit nameplate.
13. Check all piping joints and electrical connections for tightness.
14. Turn on the gas supply to unit.
15. Measure the gas pressure. If the pressure exceeds 14 inches water column (34.8 mbar), reset the regulator at the gas supply.
16. Restore unit power.
17. Place the thermostat selector switch to the HEAT position and adjust the setpoint indicator to its highest setting. The burners should light.
18. Adjust the unit manifold pressure to 10 inches water column (24.9 mbar) per the rating plate.
19. Install the access panel.

Trane and American Standard create comfortable, energy efficient indoor environments for commercial and residential applications. For more information, please visit trane.com or americanstandardair.com.

Trane and American Standard have a policy of continuous product and product data improvement and reserve the right to change design and specifications without notice. We are committed to using environmentally conscious print practices.