

# Installation Instructions

## **Economizer**

Precedent™ Packaged Rooftop Units with

Symbio™ 700 Controls

3 to 12.5 Tons

**Model Number:**

FIAECON001\*

FIAECON002\*

**Used With:**

Precedent A cabinet (Digit 39 = A)

Precedent B and C cabinet (Digit 39 = B, C)

### **⚠ SAFETY WARNING**

Only qualified personnel should install and service the equipment. The installation, starting up, and servicing of heating, ventilating, and air-conditioning equipment can be hazardous and requires specific knowledge and training. Improperly installed, adjusted or altered equipment by an unqualified person could result in death or serious injury. When working on the equipment, observe all precautions in the literature and on the tags, stickers, and labels that are attached to the equipment.

# Introduction

Read this manual thoroughly before operating or servicing this unit.

## Warnings, Cautions, and Notices

Safety advisories appear throughout this manual as required. Your personal safety and the proper operation of this machine depend upon the strict observance of these precautions.

The three types of advisories are defined as follows:

**⚠ WARNING** Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.

**⚠ CAUTION** Indicates a potentially hazardous situation which, if not avoided, could result in minor or moderate injury. It could also be used to alert against unsafe practices.

**NOTICE** Indicates a situation that could result in equipment or property-damage only accidents.

## Important Environmental Concerns

Scientific research has shown that certain man-made chemicals can affect the earth's naturally occurring stratospheric ozone layer when released to the atmosphere. In particular, several of the identified chemicals that may affect the ozone layer are refrigerants that contain Chlorine, Fluorine and Carbon (CFCs) and those containing Hydrogen, Chlorine, Fluorine and Carbon (HCFCs). Not all refrigerants containing these compounds have the same potential impact to the environment. Trane advocates the responsible handling of all refrigerants.

## Important Responsible Refrigerant Practices

Trane believes that responsible refrigerant practices are important to the environment, our customers, and the air conditioning industry. All technicians who handle refrigerants must be certified according to local rules. For the USA, the Federal Clean Air Act (Section 608) sets forth the requirements for handling, reclaiming, recovering and recycling of certain refrigerants and the equipment that is used in these service procedures. In addition, some states or municipalities may have additional requirements that must also be adhered to for responsible management of refrigerants. Know the applicable laws and follow them.

### ⚠ WARNING

#### Proper Field Wiring and Grounding Required!

Failure to follow code could result in death or serious injury.

All field wiring **MUST** be performed by qualified personnel. Improperly installed and grounded field wiring poses **FIRE** and **ELECTROCUTION** hazards. To avoid these hazards, you **MUST** follow requirements for field wiring installation and grounding as described in **NEC** and your local/state/national electrical codes.

### ⚠ WARNING

#### Personal Protective Equipment (PPE) Required!

Failure to wear proper PPE for the job being undertaken could result in death or serious injury.

Technicians, in order to protect themselves from potential electrical, mechanical, and chemical hazards, **MUST** follow precautions in this manual and on the tags, stickers, and labels, as well as the instructions below:

- **Before installing/servicing this unit, technicians MUST put on all PPE required for the work being undertaken (Examples; cut resistant gloves/sleeves, butyl gloves, safety glasses, hard hat/bump cap, fall protection, electrical PPE and arc flash clothing). ALWAYS refer to appropriate Safety Data Sheets (SDS) and OSHA guidelines for proper PPE.**
- **When working with or around hazardous chemicals, ALWAYS refer to the appropriate SDS and OSHA/GHS (Global Harmonized System of Classification and Labelling of Chemicals) guidelines for information on allowable personal exposure levels, proper respiratory protection and handling instructions.**
- **If there is a risk of energized electrical contact, arc, or flash, technicians MUST put on all PPE in accordance with OSHA, NFPA 70E, or other country-specific requirements for arc flash protection, PRIOR to servicing the unit. NEVER PERFORM ANY SWITCHING, DISCONNECTING, OR VOLTAGE TESTING WITHOUT PROPER ELECTRICAL PPE AND ARC FLASH CLOTHING. ENSURE ELECTRICAL METERS AND EQUIPMENT ARE PROPERLY RATED FOR INTENDED VOLTAGE.**

**⚠ WARNING****Follow EHS Policies!**

Failure to follow instructions below could result in death or serious injury.

- All Trane personnel must follow the company's Environmental, Health and Safety (EHS) policies when performing work such as hot work, electrical, fall protection, lockout/tagout, refrigerant handling, etc. Where local regulations are more stringent than these policies, those regulations supersede these policies.
- Non-Trane personnel should always follow local regulations.

**⚠ WARNING****R-454B Flammable A2L Refrigerant!**

Failure to use proper equipment or components as described below could result in equipment failure, and possibly fire, which could result in death, serious injury, or equipment damage.

The equipment described in this manual uses R-454B refrigerant which is flammable (A2L). Use ONLY R-454B rated service equipment and components. For specific handling concerns with R-454B, contact your local representative.

**⚠ WARNING****Cancer and Reproductive Harm!**

This product can expose you to chemicals including lead and bisphenol A (BPA), which are known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov).

## Copyright

This document and the information in it are the property of Trane, and may not be used or reproduced in whole or in part without written permission. Trane reserves the right to revise this publication at any time, and to make changes to its content without obligation to notify any person of such revision or change.

## Trademarks

All trademarks referenced in this document are the trademarks of their respective owners.

## Revision History

- Added the Help Center topic to the Introduction chapter.
- Updated Model number information in Front cover page.
- Updated General Information chapter.
- Updated Field Installed Assembly and Installation FIAECON001\*/02\* chapter.

## Help Center

For detailed information and a link to Technical Support, scan the QR code below to access the Commercial Support Help Center. From the landing page, navigate to **Light Commercial Rooftop/Splits > Precedent > SYMBIO 700 > Accessories**, then select your specific field-installed accessory.



# General Information

## Inspection

- 1. Unpack all components of the kit.
- 2. Check carefully for shipping damage. If any damage is found, report it immediately, and file a claim against the transportation company.

## Parts List

Table 1. Parts list

Qty	Description
1	Economizer assembly
1	Mist eliminator

Table 1. Parts list (continued)

Qty	Description
1	Wire tie
10	Screws
1	Actuator harness
1	Grommet
1	Duct block-off plate
12	Screws
1	Bottom block-off

# Field Installed Assembly and Installation FIAECON001\*/02\*


This section covers installation of economizer units not installed in the rooftop unit at the factory.

## Unpack Economizer

See [Figure 1, p. 5](#).

1. Uncrate the economizer and locate all parts. Each economizer ships with items economizer bottom block-off (A), economizer side bracket (B), and adapter backing plate (C) attached.
2. Remove screws completely from items (A) and (B). Retain them for reassembly.
3. Remove item (C) by loosening the three screws but do not remove them.

**Figure 1. Unpacking the economizer**




## Assembling the End Panel

See [Figure 2, p. 5](#).

1. Remove unit end economizer panel (D), retain the screws removed from the top and the bottom of panel for later use.
2. Align three slots in (D) with three tabs on economizer side panel (E).
3. Pivot (D) into place.
4. Align three tabs on (B) with three slots in (D).
5. Pivot (B) into place.
6. Secure (B) with three screws to the economizer side panel.

**Figure 2. Assembling the end panel**




## Reconfigure the Damper (For Horizontal Installation Only)

The economizer damper is pre-configured at the factory for downflow applications. Reconfigure the damper for horizontal applications.

See [Figure 3, p. 5](#) for disassembly

1. Remove two screws from (G).
2. Remove nut and disassemble (H).
3. Remove six screws from (I) (three in each location).
4. Make two cuts at (J).
5. Detach and discard (K).


**Figure 3. Disassembling the damper**



See Figure 4, p. 6 for reassembly.

1. Attach two screws at each location (I).
2. Connect (L). Do not allow more than 0.25 inch. (6.25 mm) of rod to protrude through the ball joint at (M).
3. If the unit has a smoke detector, remove knockout (N).

Figure 4. Reassemble the damper



## Optional Sensors

If the optional sensors for humidity and temperature monitoring are needed (FIAENTH001\* and FIAENTH002\*), install them using the instructions provided in those kits.

## Install Duct Block-off Plate (Downflow Units Only)

**Important:** If power exhaust or barometric relief accessory kits are installed along with an economizer, do not install the duct block-off plate.


See Figure 5, p. 6.

- For units without a smoke detector, install (O) with flange (P) pointing down.
- For units with a smoke detector, remove knockout (Q), and then install (O) with flange (P) pointing up.

Figure 5. Installing the duct block-off plate

Without smoke detector


With smoke detector



## Install Economizer into the Rooftop Unit


See Figure 1, p. 5, Figure 6, p. 6, and Figure 7, p. 7.

Figure 6. Installation of economizer assembly



1. Lift the assembled economizer into position.
2. Fit the upper left-hand corner around the channel in the cabinet post.
3. Pivot the economizer into the opening in the cabinet.
4. Once the economizer is in place, lift the economizer and panel assembly to align the upper screw holes.
5. Secure the top left and top right with screws (R) and (S) respectively.
6. Pull out the bottom of the economizer and secure bottom left with screw (T).
7. Remove the filter access panel.
8. Position (C) inside the filter section. (C) will slip over the three screws that were loosened in Figure 1, p. 5.
9. Align the engagement screw hole in (C), with the screw clearance hole at the bottom of the right corner post.
10. Secure the bottom right side of the economizer with a screw (U).
11. Install A and secure it with three screws (V).
12. Using field supplied silicone, apply sealant around economizer hood (W).

Figure 7. Sealing and seams



## Factory Installed Economizer Setup

This section covers setup of economizer units that have been installed in the rooftop unit at the factory.

### Downflow Configuration

See [Figure 7, p. 7](#), [Figure 8, p. 7](#), and [Figure 9, p. 7](#).

1. Remove filter access panel.
2. Remove the screw that holds bottom block-off (A) in place and remove bottom block-off (A), from its shipping location.
3. Remove the bottom three screws (V) from the economizer panel (D).
4. Pull the economizer assembly out into operating position.
5. Secure the economizer assembly with two screws (T and U) at the bottom of the corner posts.
6. Install bottom block-off (A) and secure with three screws (V).
7. Using field supplied silicone, apply sealant around economizer hood (W). See [Figure 7, p. 7](#).

Figure 8. Removing the bottom block-off





Figure 9. Fastening the economizer and bottom block-off



### Horizontal Configuration

See [Figure 1, p. 5](#) and [Figure 5, p. 6](#).

1. Remove filter access panel.
2. Remove (B), shown in [Figure 1, p. 5](#). (Leave the screws loosely in place).
3. Remove the bottom three screws and top two screws from the economizer panel.
4. Remove (O), shown in [Figure 5, p. 6](#).
5. Pull the economizer assembly and end panel out of the unit.
6. Reconfigure the damper for horizontal operation. See [“Reconfigure the Damper \(For Horizontal Installation](#)

Only),” p. 5 for instructions, and then return to this procedure.

7. If optional sensors for humidity and temperature monitoring will be used (FIAENTH001\* and FIAENTH002\*), install them at this step. Use the instructions provided in those kits.
8. Remove supply and return duct covers from the horizontal openings and install over the downflow openings.
9. Reinstall the economizer. See “Install Economizer into the Rooftop Unit,” p. 6 for instructions.

### Symbio Wiring Connections

**Important:** After installation is complete, update the Symbio™ 700 configuration to enable this installed feature.

Using the supplied harness connect PPF87 (black connector) to the actuator connector. Route harness to fresh air options module located in the return section and connect to FAOM-J11 (blue connector).

### Minimum Position Setting

To adjust the minimum position setting and check out the economizer, the power must be connected.

1. Close the unit disconnect and place the zone sensor fan selector in the fan **ON** position and the heat/cool selector in the **OFF** position. This will place the damper in the minimum ventilation position.

2. To adjust the minimum position setting for the required ventilation air, use the Symbio™ service and installation mobile app or Symbio 700 on-board UI to adjust the economizer minimum position setpoint BAS in the fresh/return air settings menu. The damper will open to this setting each time the blower circuit is energized.

When adjusting minimum position, the damper may move to the new setting in several small steps. Once the damper has remained in position for 10 to 15 seconds without movement, it can be assumed it is at the new position.

3. Replace the filter access panel.

The damper will close when the blower circuit is de-energized.

### Dry Bulb Settings

Standard economizer dry bulb changeover is field selectable and has a range of 50°F to 140°F.

### Reference Enthalpy Settings

Economizer enthalpy changeover is field selectable and has a range of 50°F to 140°F. The default is 60°F. This selection can be made using the Symbio™ service and installation mobile app or Symbio 700 on-board UI.

**Table 2. Precedent economizer control options**

Control Option	Enable Conditions	Option Sensor Required
Comparative Enthalpy	Outside Air Enthalpy < Return Air Enthalpy – Econ Enthalpy Offset AND Outside Air Temperature < Economizer Drybulb Setpoint – Econ DryBulb Offset	Outdoor Air Temperature Sensor Outdoor Air Humidity Sensor Return Air Temperature Sensor Return Air Humidity Sensor
Reference Enthalpy	Outside Air Enthalpy < Reference Enthalpy Setpoint – Econ Enthalpy Offset AND Outside Air Temperature < Economizer Drybulb Setpoint - Econ DryBulb Offset	Outdoor Air Temperature Sensor Outdoor Air Humidity Sensor
Dry Bulb	OA Temp < [Economizer Outdoor Air Enable Setpoint BAS - Economizer Dry Bulb Enable Offset]	Outdoor Air Temperature Sensor
Differential Dry Bulb	OA Temp < RA Temp - Economizer Dry Bulb Enable Offset - Economizer Dry Bulb Disable Return Air Offset	Outdoor Air Temperature Sensor Return Air Temperature Sensor

### Wire Routing

Using the supplied harness connect PPF87 to the actuator connector. Route harness to fresh air options module located in the return section and connect to FAOM-J11. See Figure 10, p. 9.

Figure 10. Wire harness to fresh air options module



Figure 12. Wire routing to fresh air options module



### Wiring Connections

**Important:** After installation is complete, update the Symbio™ 700 configuration to enable this installed feature.

Refer to main unit schematic sheet 6 for electrical connections to fresh air options module located in return section control box, See Figure 11, p. 9.

See *Symbio™ 700 Controller with Precedent™ Packaged Rooftop Air-Conditioners, Application Guide (ACC-APG002\*-EN)*.

Figure 11. Fresh air options module location



Fresh air options module access (A, B, and C cabinet)





Trane and American Standard create comfortable, energy efficient indoor environments for commercial and residential applications. For more information, please visit [trane.com](http://trane.com) or [americanstandardair.com](http://americanstandardair.com).

Trane and American Standard have a policy of continuous product and product data improvement and reserve the right to change design and specifications without notice. We are committed to using environmentally conscious print practices.

ACC-SVN261C-EN 13 Feb 2026  
Supersedes ACC-SVN261B-EN (September 2024)

©2026