



Installation Instructions

BR2032 Coin Cell Battery Kit

Order Number: X13641443001

Packaged Contents

- One (1) BR2032 Battery Coin Cell Kit
- One (1) Installation sheet

X39641336001

SAFETY WARNING

Only qualified personnel should install and service the equipment. The installation, starting up, and servicing of heating, ventilating, and air-conditioning equipment can be hazardous and requires specific knowledge and training. Improperly installed, adjusted or altered equipment by an unqualified person could result in death or serious injury. When working on the equipment, observe all precautions in the literature and on the tags, stickers, and labels that are attached to the equipment.

June 2020

BAS-SVN142C-EN

© 2020 Trane



1

Warnings, Cautions, and Notices

Read this manual thoroughly before operating or servicing this unit. Safety advisories appear throughout this manual as required. Your personal safety and the proper operation of this machine depend upon the strict observance of these precautions.

The three types of advisories are defined as follows:

WARNING

Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.

CAUTION

Indicates a potentially hazardous situation which, if not avoided, could result in minor or moderate injury. It could also be used to alert

NOTICE

Indicates a situation that could result in equipment or property-damage only accidents.

WARNING

Proper Field Wiring and Grounding Required!

Failure to follow code could result in death or serious injury. All field wiring MUST be performed by qualified personnel. Improperly installed and grounded field wiring poses FIRE and ELECTROCUTION hazards. To avoid these hazards, you MUST follow requirements for field wiring installation and grounding as described in NEC and your local/state electrical codes.

WARNING

Personal Protective Equipment Required!

Installing/servicing this unit could result in exposure to electrical, mechanical and chemical hazards. Before installing/servicing this unit, technicians MUST put on all Personal Protective Equipment (PPE) recommended for the work being undertaken. ALWAYS refer to appropriate SDS sheets and OSHA guidelines for proper PPE. When working with or around hazardous chemicals, ALWAYS refer to the appropriate SDS sheets and OSHA guidelines for information on allowable personal exposure levels, proper respiratory protection and handling recommendations. If there is a risk of arc or flash, technicians MUST put on all necessary Personal Protective Equipment (PPE) in accordance with NFPA70E for arc/flash protection PRIOR to servicing the unit. Failure to follow recommendations could result in death or serious injury.

2

NOTICE

Risk of Battery Exploding!

Failure to follow instructions below could cause the battery to explode resulting in equipment damage. Do NOT use a non-compatible battery with the controller! It is critical that a compatible battery be used.

Risque d'Explosion de la Pile!

Le non-respect des instructions qui suivent pourrait provoquer l'explosion de la pile et des dégâts à l'équipement. Ne PAS utiliser de pile non compatible avec le contrôleur! Il est très important qu'une pile compatible soit utilisée.

Replacing the Battery

The BR2032 Coin Cell battery extends the preservation of the date and time of the device in the event of a power loss.


Note: In order to maintain the current date and time in the controller, **do not** power down the device when replacing the battery. If not possible, power up the device as soon as possible after installing/replacing the battery.

Refer to figure 1 on Panel 3.

1. Pry open the battery compartment on the front of the controller.
2. Remove the old battery. Dispose of, or recycle, in compliance with local ordinances.
3. Insert the BR2032 in the battery compartment. Securely (but gently) close the battery compartment.

3

Figure 1. Removing and replacing the battery



Trane - by Trane Technologies (NYSE: TT), a global climate innovator - creates comfortable, energy efficient indoor environments for commercial and residential applications. For more information, please visit trane.com or tranetechnologies.com.

Trane has a policy of continuous product and product data improvement and reserves the right to change design and specifications without notice. We are committed to using environmentally conscious print practices.

BAS-SVN142C-EN 08 Jun 2020
Supersedes X39641336001B (Jan 2018)

©2020 Trane