



Profile Definition and Network Variables

The following tables are sorted as follows:

- Tables are listed by unit/profile type and sorted by network variable number.
- Tables are sorted by name and provide a complete list of names, types, values/ranges, and descriptions.

Note: Not all points are available to the user. The available data points are defined during self-configuration and are dependent on the type of equipment.

Symbio™ 700 Integration Points List

LonTalk®

Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024

Firmware Release: V7.00.0011

Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Recv HrtBt	SNVT	Variable Description
37	nviApplicMode	♥	SNVT_hvac_mode	Heat Cool Mode Request
38	nviAuxHeatEnable	♥	SNVT_switch	Heat Auxiliary Enable
39	nviBldgStaticSP		SNVT_press_p	Building Static Pressure Setpoint
40	nviBldgStatPress	♥	SNVT_press_p	Building Static Pressure
41	nviComprEnable	♥	SNVT_switch	Compressor Cooling Enable BAS
42	nviCWFlow	♥	SNVT_switch	Condenser Water Flow BAS
43	nviDACISP		SNVT_temp_p	Discharge Air Cooling Setpoint BAS
44	nviDAHTSP		SNVT_temp_p	Discharge Air Heating Setpoint BAS
45	nviDAREheatSP		SNVT_temp_p	Discharge Air Reheat Setpoint BAS
46	nviDehumEnable	♥	UNVT_switch_binary	Dehumidification System Enable BAS
47	nviEconEnable	♥	UNVT_switch_multistate	Economizer Enable BAS
48	nviEmergOverride	♥	SNVT_hvac_emerg	Emergency Override BAS
49	nviHumEnable	♥	UNVT_switch_binary	Humidification Enable BAS
50	nviOAMinPos		SNVT_lev_percent	Economizer Minimum Position Setpoint
51	nviOccManCmd		SNVT_lev_percent	Occupancy Request
52	nviOccSchedule	♥	SNVT_lev_percent	Occupancy Request
53	nviOccSensor	♥	SNVT_occupancy	Occupancy Input BAS
54	nviOutdoorRH	♥	SNVT_lev_percent	Outdoor Air Relative Humidity BAS
55	nviOutdoorTemp	♥	SNVT_temp_p	Outdoor Air Temperature BAS
56	nviRTUConfig		SNVT_state Rooftop	Configuration
	nviRTUConfig.0		(MSB) Bit 0	Reserved
	nviRTUConfig.1		Bit 1	Cooling Lockout
	nviRTUConfig.2		Bit 2	Heating Lockout
	nviRTUConfig.3		Bit 3	Demand Limit Request BAS
	nviRTUConfig.4		Bit 4	Energy Consumption Reset
	nviRTUConfig.5		Bit 5	Supply Fan Compensation
	nviRTUConfig.6		Bit 6	PreCool Enable Command
	nviRTUConfig.7		Bit 7	Morning Warmup Enable Command
	nviRTUConfig.8		Bit 8	Supply Air Tempering Request BAS
	nviRTUConfig.9		Bit 9	Daytime Warmup Enable Command
	nviRTUConfig.10		Bit 10	Timed Override Request (with Bit 11)

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Recv HrtBt	SNVT	Variable Description
	nviRTUConfig.11		Bit 11	Timed Override Request 00 Idle 01 On 10 Cancel 11 Invalid
	nviRTUConfig.12		Bit 12	Reserved
	nviRTUConfig.13		Bit 13	Reserved
	nviRTUConfig.14		Bit 14	Reserved
	nviRTUConfig.15		(LSB) Bit 15	Reserved
57	nviRequest		SNVT_obj_request	Reset Diagnostic Request
58	nviSetpoint		SNVT_temp_p	Space Temperature Setpoint BAS
59	nviSetptOffset	♥	SNVT_temp_p	Space Setpoint Offset BAS
60	nviSetptShift	♥	SNVT_temp_setpt	Space Setpoint Shift BAS
61	nviSpaceCO2	♥	SNVT_ppm	Space CO2 Concentration BAS
62	nviSpaceDehumSP		SNVT_lev_percent	Space Dehumidification Setpoint BAS
63	nviSpaceHumSP		SNVT_lev_percent	Space Humidity Setpoint BAS
64	nviSpaceRH	♥	SNVT_lev_percent	Space Relative Humidity BAS
65	nviSpaceTemp	♥	SNVT_temp_p	Space Temperature BAS
66	nviTraneVar2		UNVT_c5c	Manufacturer-defined

Note: Grayed out LONtalk network variables are not supported.

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date:11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
67	nvoAlarmMessage		SNVT_str_asc	Diagnostic Last Message
68	nvoBldgStatPress	▼	SNVT_press_p Space	Static Pressure Active
69	nvoCondCap	▼	SNVT_lev_percent	Condenser Capacity
70	nvoCoolPrimary	▼	UNVT_switch_binary	Cooling Capacity Status
71	nvoCprsrRunning	▼	SNVT_state	Compressor Status
	nvoCprsrRunning.0		(MSB) Bit 0	Validity of bit 8
	nvoCprsrRunning.1		Bit 1	Validity of bit 9
	nvoCprsrRunning.2		Bit 2	Validity of bit 10
	nvoCprsrRunning.3		Bit 3	Validity of bit 11
	nvoCprsrRunning.4		Bit 4	Validity of bit 12
	nvoCprsrRunning.5		Bit 5	Validity of bit 13
	nvoCprsrRunning.6		Bit 6	Validity of bit 14
	nvoCprsrRunning.7		Bit 7	Validity of bit 15
	nvoCprsrRunning.8		Bit 8	Compressor 1A Status
	nvoCprsrRunning.9		Bit 9	Compressor 1B Status
	nvoCprsrRunning.10		Bit 10	Compressor 1C Status
	nvoCprsrRunning.11		Bit 11	Compressor 1D Status
	nvoCprsrRunning.12		Bit 12	Compressor 2A Status
	nvoCprsrRunning.13		Bit 13	Compressor 2B Status
	nvoCprsrRunning.14		Bit 14	Compressor 2C Status
	nvoCprsrRunning.15		(LSB) Bit 15	Compressor 2D Status
72	nvoCWFlow	▼	SNVT_switch	Condenser Water Flow Status
73	nvoCWPump	▼	SNVT_switch	Condenser Water Pump Status
74	nvoCWTemp	▼	SNVT_temp_p	Condenser Water Temperature
75	nvoDARheatSP	▼	SNVT_temp_p	Discharge Air Reheat Setpoint Active
76	nvoDehumidifier	▼	SNVT_switch	Dehumidification Control Status
77	nvoDischAirTemp	▼	SNVT_temp_p	Discharge Air Temperature
78	nvoEffectOccup	▼	SNVT_occupancy	Occupancy Status
79	nvoEffectSetpt	▼	SNVT_temp_p	Space Temperature Setpoint Active
80	nvoEffSpaceHumSP	▼	SNVT_lev_percent	Space Humidity Active
81	nvoEREABPDamper	▼	SNVT_lev_percent	Energy Recovery Exhaust Air Bypass Damper Position

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
82	nvoERFrostAvoid	♥	SNVT_switch	Energy Recovery Frost Avoidance Status
83	nvoERLvgExhTemp	♥	SNVT_temp_p	Energy Recovery Leaving Exhaust Temperature Status
84	nvoEROABPDamper	♥	SNVT_lev_percent	Energy Recovery Outdoor Air Bypass Damper Status
85	nvoERPreheat	♥	SNVT_switch	Energy Recovery Preheat Status
86	nvoERStatus	♥	SNVT_switch	Energy Recovery Status
87	nvoExhDamper	♥	SNVT_lev_percent	Exhaust Damper Position
88	nvoExhFanOnOff	♥	SNVT_switch	Exhaust Fan Output Status
89	nvoExhFanStatus	♥	SNVT_switch	Exhaust Fan Speed Status
90	nvoFanSpeed		SNVT_switch	Fan Speed Status
91	nvoFDD		SNVT_state	Fault Detection and Diagnostics
	nvoFDD.0		(MSB) Bit 0	Diagnostic: Not Economizing When Should Be
	nvoFDD.1		Bit 1	Diagnostic: Economizing When Should Not
	nvoFDD.2		Bit 2	Diagnostic: Excessive Outdoor Air Flow
	nvoFDD.3		Bit 3	Diagnostic: Mixed Air Low Temperature Cycle
	nvoFDD.4		Bit 4	Diagnostic: Mixed Air Temperature Sensor Failure
	nvoFDD.5		Bit 5	Diagnostic: Outdoor Air Damper Not Modulating
	nvoFDD.6		Bit 6	Diagnostic: Outdoor Air Temperature Sensor Failure
	nvoFDD.7		Bit 7	Diagnostic: Return Air Temperature Sensor Failure
	nvoFDD.8		Bit 8	Diagnostic: Supply Air Temperature Sensor Failure
	nvoFDD.9		Bit 9	Reserved
	nvoFDD.10		Bit 10	Reserved
	nvoFDD.11		Bit 11	Reserved
	nvoFDD.12		Bit 12	Reserved
	nvoFDD.13		Bit 13	Reserved
	nvoFDD.14		Bit 14	Reserved
	nvoFDD.15		(LSB) Bit 15	Reserved
92	nvoHeatCool	♥	SNVT_hvac_mode	Heat Cool Mode Status
93	nvoHeatPrimary	♥	SNVT_lev_percent	Heating Capacity Primary Status
94	nvoHeatSecondary	♥	SNVT_lev_percent	Heating Capacity Secondary Status
95	nvoHumidifier	♥	SNVT_lev_percent	Humidification Capacity Status
96	nvoLocalCWTemp	♥	SNVT_temp_p	Condenser Water Temperature Local

Symbio™ 700 Integration Points List

LonTalk®

Precedent® and Axiom™ Rooftop WSHP

Date:11/08/2024

Firmware Release: V7.00.0011

Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
97	nvoLocalSpaceTmp	♥	SNVT_temp_p	Space Temperature Local
98	nvoMixedAirTemp	♥	SNVT_temp_p	Mixed Air Temperature Local
99	nvoOADamper	♥	SNVT_lev_percent	Outdoor Air Damper Position
100	nvoOAEnthalpy	♥	SNVT_enthalpy	Outdoor Air Enthalpy Active
101	nvoOAFlow	♥	FNVT_flow	Outdoor Air Flow Active
102	nvoOutdoorRH	♥	SNVT_lev_percent	Outdoor Air Humidity Active
103	nvoOutdoorTemp	♥	SNVT_temp_p	Outdoor Air Temperature Active
104	nvoRATemp	♥	SNVT_temp_p	Return Air Temperature
105	nvoRetFanOnOff	♥	SNVT_switch	Return Fan Output Status
106	nvoRetFanPress	♥	SNVT_press_p	Return Fan Air Pressure
107	nvoRetFanStatus	♥	SNVT_switch	Return Fan Speed Status
108	nvoRTUStatus	♥	SNVT_state	Rooftop Status
	nvoRTUStatus.0	♥	(MSB) Bit 0	Unit Running State
	nvoRTUStatus.1	♥	Bit 1	Emergency Stop
	nvoRTUStatus.2	♥	Bit 2	External Auto Stop Input Status
	nvoRTUStatus.3	♥	Bit 3	Condensate Overflow Input
	nvoRTUStatus.4	♥	Bit 4	Timed Override Status (with Bit 5)
	nvoRTUStatus.5	♥	Bit 5	Timed Override Status 00 Idle 01 On 10 Cancel
	nvoRTUStatus.6	♥	Bit 6	Precool Mode Status
	nvoRTUStatus.7	♥	Bit 7	Morning Warmup Running
	nvoRTUStatus.8	♥	Bit 8	Supply Air Tempering Status
	nvoRTUStatus.9	♥	Bit 9	Daytime Warmup Running
	nvoRTUStatus.10	♥	Bit 10	Reserved
	nvoRTUStatus.11	♥	Bit 11	Compressor Lockout Status
	nvoRTUStatus.12	♥	Bit 12	Coil Frost Protection Status, Circuit 1
	nvoRTUStatus.13	♥	Bit 13	Coil Frost Protection Status, Circuit 2
	nvoRTUStatus.14	♥	Bit 14	Rapid Restart Status
	nvoRTUStatus.15	♥	(LSB) Bit 15	Reserved
109	nvoSetpoint	♥	SNVT_temp_p	Space Temperature Setpoint Local
110	nvoSpaceCO2	♥	SNVT_ppm	Space CO2 Concentration Active

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date:11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
111	nvoSpaceEnthalpy	♥	SNVT_enthalpy	Return Air Enthalpy Active
112	nvoSpaceRH	♥	SNVT_lev_percent	Space Humidity Active
113	nvoSpaceTemp	♥	SNVT_temp_p	Space Temperature Active
114	nvoStartsRunTmA	♥	UNVT_starts_runtime	Starts - Compressor 1A
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
115	nvoStartsRunTmB	♥	UNVT_starts_runtime	Starts - Compressor 1B
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
116	nvoStartsRunTmC	♥	UNVT_starts_runtime	Starts - Compressor 1C
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
117	nvoStartsRunTmD	♥	UNVT_starts_runtime	Starts - Compressor 2A
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
118	nvoStartsRunTmE	♥	UNVT_starts_runtime	Starts - Compressor 2B
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
119	nvoStartsRunTmF	♥	UNVT_starts_runtime	Starts - Compressor 2C
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
120	nvoStatus	♥	SNVT_obj_status	Local Setpoint Control
121	nvoSucRfgtPrsC1	♥	SNVT_press_f	Suction Refrigerant Pressure, Circuit 1
122	nvoSucRfgtPrsC2	♥	SNVT_press_f	Suction Refrigerant Pressure, Circuit 2
123	nvoSucRfgtTmpC1	♥	SNVT_temp_p	Suction Refrigerant Temperature, Circuit 1
124	nvoSucRfgtTmpC2	♥	SNVT_temp_p	Suction Refrigerant Temperature, Circuit 2
125	nvoDschRfgtPrsC1	♥	SNVT_press_f	Discharge Refrigerant Pressure, Circuit 1
126	nvoDschRfgtPrsC2	♥	SNVT_press_f	Discharge Refrigerant Pressure, Circuit 2
127	nvoDisSatRfgTmp1	♥	SNVT_temp_p	Discharge Refrigerant Temperature, Circuit 1
128	nvoDisSatRfgTmp2	♥	SNVT_temp_p	Discharge Refrigerant Temperature, Circuit 2
129	nvoAirFlowPctC1	♥	SNVT_lev_percent	Air Flow Percentage, Circuit 1
130	nvoAirFlowPctC2	♥	SNVT_lev_percent	Air Flow Percentage, Circuit 2

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
131	nvoTerminalLoad	♥	SNVT_lev_percent	Unit Energy Demand
132	nvoTraneVar9		UNVT_c5s	Manufacturer-defined
133	nvoUnitCurrent	♥	UNVT_3phase_current	Unit Current Per Line
	nvoUnitCurrent (bytes 1-2)	♥	SNVT_amp_ac	Current L1, in Amps
	nvoUnitCurrent (bytes 3-4)	♥	SNVT_amp_ac	Current L2, in Amps
	nvoUnitCurrent (bytes 5-6)	♥	SNVT_amp_ac	Current L3, in Amps
	nvoUnitCurrent (bytes 7-8)	♥		Invalid
	nvoUnitCurrent (bytes 9-10)	♥		Invalid
	nvoUnitCurrent (bytes 11-12)	♥		Invalid
134	nvoUnitPower	♥	SNVT_power_f	Unit Power Consumption
135	nvoUnitStatus	♥	SNVT_hvac_status	Unit Status
	nvoUnitStatus (byte 1)	♥	.mode	Mode Status
	nvoUnitStatus (bytes 2-3)	♥	.heat_output_primary	Heating Capacity Primary Status
	nvoUnitStatus (bytes 4-5)	♥	.heat_output_secondary	Heating Capacity Secondary Status
	nvoUnitStatus (bytes 6-7)	♥	.cool_output	Cooling Capacity Status
	nvoUnitStatus (bytes 8-9)	♥	.econ_output	Economizer Status
	nvoUnitStatus (bytes 10-11)	♥	.fan_output	Supply Fan Speed Status
	nvoUnitStatus (byte 12)	♥	.in_alarm	In Alarm
136	nvoUnitVoltage	♥	UNVT_3Phase_volt	Unit Voltage
	nvoUnitVoltage (bytes 1-2)	♥	SNVT_volt_ac	Voltage AB
	nvoUnitVoltage (bytes 3-4)	♥	SNVT_volt_ac	Voltage BC
	nvoUnitVoltage (bytes 5-6)	♥	SNVT_volt_ac	Voltage CA

Note: Grayed out LONtalk network variables are not supported.

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	SNVT	Variable Description
0	nciBldgStaticSP	SNVT_press_p	Space Static Pressure Setpoint
1	nciBypassTime	SNVT_time_min	Occupied Bypass Time
2	nciCabinetStyle	UCPT_cabinet_style	Cabinet Style ^(a)
3	nciCool	UCPT_cool_type	Cool Type ^(a)
4	nciCRC	UCPT_crc	Manufacturer-defined ^(a)
5	nciDACISP	SNVT_temp_p	Discharge Air Cooling Setpoint
6	nciDAHtSP	SNVT_temp_p	Discharge Air Heating Setpoint
7	nciDAReheatSP	SNVT_temp_p	Discharge Air Reheat Setpoint
8	nciDevBuildNum	U16	Device Build Number
9	nciDeviceConfig	UCPTdeviceConfig	Manufacturer-defined ^(a)
10	nciDevMajVer	SCPTdevMajVer	Software Major Version
11	nciDevMinVer	SCPTdevMinVer	Software Minor Version
12	nciEconConfigTyp	UCPT_econo_config_type	Economizer Decision Method ^(a)
13	nciEconVent	UCPT_OA_type	Economizer Type Identifier ^(a)
14	nciERFrostAvodSP	UCPT_ERFrostAvoidSP	Energy Recovery Frost Avoidance Temp Setpoint ^(a)
15	nciExhaustConfig	UCPT_exhaust_cfg	Exhaust Enable Position Setpoint ^(a)
16	nciExhRet	UCPT_ER_type	Exhaust Or Return Fan Type ^(a)
17	nciFanOperation	SCPTfanOperation	Supply Fan Configuration Command
18	nciHvacType	SNVT_hvac_type	HVAC Unit Type Identifier
19	nciLocation	SNVT_str_asc	Location Label
20	nciMinOAFlowSP	SNVT_flow	Outdoor Air Minimum Flow Setpoint BAS
21	nciMinOutTm	SNVT_time_sec	Minimum Send Time
22	nciOAEnthSP	SNVT_enthalpy	Economizer Outdoor Air Enthalpy Enable Setpoint BAS
23	nciOAMinPos	SNVT_lev_percent	Outdoor Air Damper Minimum Position
24	nciPreheat	UCPT_heat_type	Preheat Type Identifier ^(a)
25	nciRcvHrtBt	SNVT_time_sec	Receive Heartbeat
26	nciRefrigType	UCPT_refrig_type	Refrigeration Type Identifier ^(a)
27	nciReheat	UCPT_heat_type	Reheat Type Identifier ^(a)
28	nciRetFanPressSP	SNVT_press_p	Return Fan Air Pressure Setpoint

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	SNVT	Variable Description
29	nciSetpoints	SNVT_temp_setpt	Occupancy Temperature Setpoints Occupied Cool Setpoint Occupied Standby Cooling Setpoint Unoccupied Cooling Setpoint Occupied Heating Setpoint Occupied Standby Heating Setpoint Unoccupied Heating Setpoint
30	nciSndHrtBt	SNVT_time_sec	Send Heartbeat Time
31	nciSpaceCO2Lim	SNVT_ppm Space	CO2 High Limit
32	nciSpaceCO2LowLm	SNVT_ppm	Space CO2 Low Limit ^(a)
33	nciSpaceHumSP	SNVT_lev_percent	Space Humidification Setpoint
34	nciSupplyFan	UCPT_fan_type	Supply Fan Type Identifier ^(a)
35	nciUntryType	UCPT_large equip_type	Unitary Type Identifier ^(a) Model Information Cooling Source Size Heating Source Size Number of Circuits Number of Compressors, Circuit 1 Number of Compressors, Circuit 2
36	nciOATSP	SNVT_temp_p	Economizer Outdoor Air Enable Setpoint BAS

^(a) Manufacturer defined.

Note: Grayed out LONtalk network variables are not supported.

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Recv HrtBt	SNVT	Variable Description
42	nviApplicMode	♥	SNVT_hvac_mode	Heat Cool Mode Request
43	nviBldgStaticSP		SNVT_press_p	Space Static Pressure Setpoint BAS
44	nviBldgStatPress	♥	SNVT_press_p	Space Static Pressure BAS
45	nviCWFlow	♥	SNVT_switch	Condenser Water Flow BAS
46	viDACISP		SNVT_temp_p	Discharge Air Cooling Setpoint BAS
47	nviDADewPointSP		SNVT_temp_p	Discharge Air Dewpoint Setpoint
48	nviDAHTSP		SNVT_temp_p	Discharge Air Heating Setpoint BAS
49	nviDARheatSP		SNVT_temp_p	Discharge Air Reheat Setpoint BAS
50	nviDehumEnable	♥	SNVT_switch	Dehumidification Enable Command
51	nviDuctStaticSP		SNVT_press_p	Duct Static Pressure Setpoint BAS
52	nviDuctStatPress	♥	SNVT_press_p	Duct Static Pressure BAS
53	nviEconEnable	♥	SNVT_switch	Economizer Airside Enable BAS
54	nviEmergOverride		SNVT_hvac_emerg	Emergency Override BAS
55	nviHumEnable	♥	SNVT_switch	Humidification Command
56	nviMinOAFFlowSP		SNVT_flow	Outdoor Air Minimum Flow Setpoint BAS
57	nviOAMinPos		SNVT_lev_percent	Economizer Minimum Position Setpoint BAS
58	nviOccManCmd		SNVT_occupancy	Occupancy Input
59	nviOccSchedule	♥	SNVT_tod_event	Occupancy Request
60	nviOutdoorRH	♥	SNVT_lev_percent	Outdoor Air Humidity BAS
61	nviOutdoorTemp	♥	SNVT_temp_p	Outdoor Air Temperature BAS
62	nviPriCoolEnable	♥	SNVT_switch	Cooling Capacity Enable
63	nviPriHeatEnable	♥	SNVT_switch	Heat Primary Enable BAS
64	nviRTUConfig		SNVT_state	Rooftop Configuration
	nviRTUConfig.0		(MSB) Bit 0	Reserved
	nviRTUConfig.1		Bit 1	Cooling Lockout
	nviRTUConfig.2		Bit 2	Heating Lockout
	nviRTUConfig.3		Bit 3	Demand Limit Request BAS
	nviRTUConfig.4		Bit 4	Energy Consumption Reset
	nviRTUConfig.5		Bit 5	Supply Fan Compensation
	nviRTUConfig.6		Bit 6	PreCool Enable Command
	nviRTUConfig.7		Bit 7	Morning Warmup Enable Command
	nviRTUConfig.8		Bit 8	Supply Air Tempering Request BAS

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Recv HrtBt	SNVT	Variable Description
	nviRTUConfig.9		Bit 9	Daytime Warmup Enable Command
	nviRTUConfig.10		Bit 10	Timed Override Request (with Bit 11)
	nviRTUConfig.11		Bit 11	Timed Override Request 00 Idle 01 On 10 Cancel 11 Invalid
	nviRTUConfig.12		Bit 12	Reserved
	nviRTUConfig.13		Bit 13	Reserved
	nviRTUConfig.14		Bit 14	Reserved
	nviRTUConfig.15		(LSB) Bit 15	Reserved
65	nviRequest		SNVT_obj_request	Reset Diagnostic Request
66	nviSpaceCO2	♥	SNVT_ppm	Space CO2 Concentration BAS
67	nviSpaceDehumSP		SNVT_lev_percent	Space Dehumidification Setpoint BAS
68	nviSpaceHumSP		SNVT_lev_percent	Space Humidification Setpoint BAS
69	nviSpaceRH	♥	SNVT_lev_percent	Space Humidity BAS
70	nviSpaceTemp	♥	SNVT_temp_p	Space Temperature BAS
71	nviTraneVar2		UNVT_c5c	Manufacturer-defined

Note: Grayed out LONtalk network variables are not supported.

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
72	nvoAlarmMessage		SNVT_str_asc	Diagnostic Last Message
73	nvoApplicMode	♥	SNVT_hvac_mode	Application Mode Output
74	nvoBldgStatPress	♥	SNVT_press_p	Space Static Pressure Active
75	nvoCondCap	♥	SNVT_lev_percent	Condenser Capacity
76	nvoCoolPrimary	♥	SNVT_lev_percent	Cooling Capacity Status
77	nvoCprsrRunning	♥	SNVT_state	Compressor Status
	nvoCprsrRunning.0	♥	(MSB) Bit 0	Bit 0 Validity of bit 8
	nvoCprsrRunning.1	♥	Bit 1	Validity of bit 9
	nvoCprsrRunning.2	♥	Bit 2	Validity of bit 10
	nvoCprsrRunning.3	♥	Bit 3	Validity of bit 11
	nvoCprsrRunning.4	♥	Bit 4	Validity of bit 12
	nvoCprsrRunning.5	♥	Bit 5	Validity of bit 13
	nvoCprsrRunning.6	♥	Bit 6	Validity of bit 14
	nvoCprsrRunning.7	♥	Bit 7	Validity of bit 15
	nvoCprsrRunning.8	♥	Bit 8	Compressor 1A Status
	nvoCprsrRunning.9	♥	Bit 9	Compressor 1B Status
	nvoCprsrRunning.10	♥	Bit 10	Compressor 1C Status
	nvoCprsrRunning.11	♥	Bit 11	Compressor 1D Status
	nvoCprsrRunning.12	♥	Bit 12	Compressor 2A Status
	nvoCprsrRunning.13	♥	Bit 13	Compressor 2B Status
	nvoCprsrRunning.14	♥	Bit 14	Compressor 2C Status
	nvoCprsrRunning.15	♥	(LSB) Bit 15	Compressor 2D Status
78	nvoCWFlow	♥	SNVT_switch	Condenser Water Flow Status
79	nvoCWPump	♥	SNVT_switch	Condenser Water Pump Status
80	nvoCWTemp	♥	SNVT_temp_p	Condenser Water Temperature
81	nvoDAReheatSP	♥	SNVT_temp_p	Discharge Air Reheat Setpoint Active
82	nvoDehumidifier	♥	SNVT_switch	Dehumidification Control Status
83	nvoDischAirTemp	♥	SNVT_temp_p	Discharge Air Temperature
84	nvoDuctStatPress	♥	SNVT_press_p	Duct Static Pressure Active
85	nvoEconEnabled	♥	SNVT_switch	Economizer Entering Water Temperature Active
86	nvoEffDADewPtSP	♥	SNVT_temp_p	Discharge Air Dewpoint Temperature Setpoint Active
87	nvoEffDATempSP	♥	SNVT_temp_p	Discharge Air Temperature Setpoint Active

Symbio™ 700 Integration Points List

LonTalk®

Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024

Firmware Release: V7.00.0011

Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
88	nvoEffDuctStatSP	♥	SNVT_press_p	Duct Static Pressure Setpoint Active
89	nvoEffectOccup	♥	SNVT_occupancy	Occupancy Status
90	nvoEffSpaceHumSP	♥	SNVT_lev_percent	Space Humidity Active
91	nvoEREABPDamper	♥	SNVT_lev_percent	Energy Recovery Exhaust Air Bypass Damper Position
92	nvoERLvgExhTemp	♥	SNVT_temp_p	Energy Recovery Leaving Exhaust Temperature Status
93	nvoEROABPDamper	♥	SNVT_lev_percent	Energy Recovery Outdoor Air Bypass Damper Status
94	nvoERPreheat	♥	SNVT_switch	Energy Recovery Preheat Status
95	nvoERStatus	♥	SNVT_switch	Energy Recovery Status
96	nvoExhDamper	♥	SNVT_lev_percent	Exhaust Damper Position
97	nvoExhFanOnOff	♥	SNVT_switch	Exhaust Fan Output Status
98	nvoExhFanStatus	♥	SNVT_switch	Exhaust Fan Speed Status
99	nvoFDD	♥	SNVT_state	Fault Detection and Diagnostics
	nvoFDD.0	♥	(MSB) Bit 0	Diagnostic: Not Economizing When Should Be
	nvoFDD.1	♥	Bit 1	Diagnostic: Economizing When Should Not
	nvoFDD.2	♥	Bit 2	Diagnostic: Excessive Outdoor Air Flow
	nvoFDD.3	♥	Bit 3	Diagnostic: Mixed Air Low Temperature Cycle
	nvoFDD.4	♥	Bit 4	Diagnostic: Mixed Air Temperature Sensor Failure
	nvoFDD.5	♥	Bit 5	Diagnostic: Outdoor Air Damper Not Modulating
	nvoFDD.6	♥	Bit 6	Diagnostic: Outdoor Air Temperature Sensor Failure
	nvoFDD.7	♥	Bit 7	Diagnostic: Return Air Temperature Sensor Failure
	nvoFDD.8	♥	Bit 8	Diagnostic: Supply Air Temperature Sensor Failure
	nvoFDD.9	♥	Bit 9	Reserved
	nvoFDD.10	♥	Bit 10	Reserved
	nvoFDD.11	♥	Bit 11	Reserved
	nvoFDD.12	♥	Bit 12	Reserved
	nvoFDD.13	♥	Bit 13	Reserved
	nvoFDD.14	♥	Bit 14	Reserved
	nvoFDD.15	♥	(LSB) Bit 15	Reserved
100	nvoHeatCool	♥	SNVT_hvac_mode	Heat Cool Mode Status
101	nvoHeatPrimary	♥	SNVT_lev_percent	Heating Capacity Primary Status
102	nvoHeatSecondary	♥	SNVT_lev_percent	Heating Capacity Secondary Status

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
103	nvoHumidifier	▼	SNVT_lev_percent	Humidification Capacity Status
104	nvoLocalCWTemp	▼	SNVT_temp_p	Condenser Water Temperature Local
105	nvoLocalDSPress	▼	SNVT_press_p	Duct Static Pressure Local
106	nvoLocalOARH	▼	SNVT_lev_percent	Outdoor Air Relative Humidity Local
107	nvoLocalOATemp	▼	SNVT_temp_p	Outdoor Air Temperature Local
108	nvoMATemp	▼	SNVT_temp_p	Mixed Air Temperature Local
109	nvoOADamper	▼	SNVT_lev_percent	Outdoor Air Damper Position
110	nvoOADewpoint	▼	SNVT_temp_p	Outdoor Air Dewpoint
111	nvoOAEenthalpy	▼	SNVT_enthalpy	Outdoor Air Enthalpy Active
112	nvoOAFlow	▼	SNVT_flow	Outdoor Air Flow Active
113	nvoOutdoorRH	▼	SNVT_lev_percent	Outdoor Air Humidity Active
114	nvoOutdoorTemp	▼	SNVT_temp_p	Outdoor Air Temperature Active
115	nvoRATemp	▼	SNVT_temp_p	Return Air Temperature
116	nvoRetFanOnOff	▼	SNVT_switch	Return Fan Output Status
117	nvoRetFanPress	▼	SNVT_press_p	Return Fan Air Pressure
118	nvoRetFanStatus	▼	SNVT_switch	Return Fan Speed Status
119	nvoRTUStatus	▼	SNVT_state	Rooftop Status
	nvoRTUStatus.0	▼	(MSB) Bit 0	Unit Running State
	nvoRTUStatus.1	▼	Bit 1	Emergency Stop
	nvoRTUStatus.2	▼	Bit 2	External Auto Stop Input Status
	nvoRTUStatus.3	▼	Bit 3	Condensate Overflow Input
	nvoRTUStatus.4	▼	Bit 4	Timed Override Status (with Bit 5)
	nvoRTUStatus.5	▼	Bit 5	Timed Override Status 00 Idle 01 On 10 Cancel
	nvoRTUStatus.6	▼	Bit 6	Precool Mode Status
	nvoRTUStatus.7	▼	Bit 7	Morning Warmup Running
	nvoRTUStatus.8	▼	Bit 8	Supply Air Tempering Status
	nvoRTUStatus.9	▼	Bit 9	Daytime Warmup Running
	nvoRTUStatus.10	▼	Bit 10	Reserved
	nvoRTUStatus.11	▼	Bit 11	Compressor Lockout Status
	nvoRTUStatus.12	▼	Bit 12	Coil Frost Protection Status, Circuit 1

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date:11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
	nvoRTUStatus.13	♥	Bit 13	Coil Frost Protection Status, Circuit 2
	nvoRTUStatus.14	♥	Bit 14	Rapid Restart Status
	nvoRTUStatus.15	♥	(LSB) Bit 15	Reserved
120	nvoSpaceCO2	♥	SNVT_ppm	Space CO2 Concentration Active
121	nvoSpaceEnthalpy	♥	SNVT_enthalpy	Return Air Enthalpy Active
122	nvoSpaceRH	♥	SNVT_lev_percent	Space Humidity Active
123	nvoSpaceTemp	♥	SNVT_temp_p	Space Temperature Active
124	nvoStartsRunTmA	♥	UNVT_starts_runtime	Starts - Compressor 1A
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
125	nvoStartsRunTmB	♥	UNVT_starts_runtime	Starts - Compressor 1B
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
126	nvoStartsRunTmC	♥	UNVT_starts_runtime	Starts - Compressor 1C
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
127	nvoStartsRunTmD	♥	UNVT_starts_runtime	Starts - Compressor 2A
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
128	nvoStartsRunTmE	♥	UNVT_starts_runtime	Starts - Compressor 2B
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
129	nvoStartsRunTmF	♥	UNVT_starts_runtime	Starts - Compressor 2C
		♥	SNVT_count_f	Starts
		♥	SNVT_time_f	Run Time
130	nvoStatus	♥	SNVT_obj_status	Local Setpoint Control
131	nvoSucRfgtPrsC1	♥	SNVT_press_f	Suction Refrigerant Pressure, Circuit 1
132	nvoSucRfgtPrsC2	♥	SNVT_press_f	Suction Refrigerant Pressure, Circuit 2
133	nvoSucRfgtTmpC1	♥	SNVT_temp_p	Suction Refrigerant Temperature, Circuit 1
134	nvoSucRfgtTmpC2	♥	SNVT_temp_p	Suction Refrigerant Temperature, Circuit 2
135	nvoDschRfgtPrsC1	♥	SNVT_press_f	Discharge Refrigerant Pressure, Circuit 1
136	nvoDschRfgtPrsC2	♥	SNVT_press_f	Discharge Refrigerant Pressure, Circuit 2

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date:11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	Send HrtBt	SNVT	Variable Description
137	nvoDisSatRfgTmp1	♥	SNVT_temp_p	Discharge Refrigerant Temperature, Circuit 1
138	nvoDisSatRfgTmp2	♥	SNVT_temp_p	Discharge Refrigerant Temperature, Circuit 2
139	nvoAirFlowPctC1	♥	SNVT_lev_percent	Air Flow Percentage, Circuit 1
140	nvoAirFlowPctC2	♥	SNVT_lev_percent	Air Flow Percentage, Circuit 2
141	nvoSupFanOnOff	♥	SNVT_switch	Supply Fan Output Status
142	nvoSupFanStatus	♥	SNVT_switch	Supply Fan Speed Status
143	nvoTraneVar9		UNVT_c5s	Manufacturer-defined
144	nvoUnitCurrent	♥	UNVT_3phase_current	Unit Current Per Line
	nvoUnitCurrent (bytes 1-2)	♥	SNVT_amp_ac	Current L1, in Amps
	nvoUnitCurrent (bytes 3-4)	♥	SNVT_amp_ac	Current L2, in Amps
	nvoUnitCurrent (bytes 5-6)	♥	SNVT_amp_ac	Current L3, in Amps
	nvoUnitCurrent (bytes 7-8)	♥		Invalid
	nvoUnitCurrent (bytes 9-10)	♥		Invalid
	nvoUnitCurrent (bytes 11-12)	♥		Invalid
145	nvoUnitPower	♥	SNVT_power_f	Unit Power Consumption
146	nvoUnitStatus	♥	SNVT_hvac_status	Unit Status
	nvoUnitStatus (byte 1)	♥	.mode	Mode Status
	nvoUnitStatus (bytes 2-3)	♥	.heat_output_primary	Heating Capacity Primary Status
	nvoUnitStatus (bytes 4-5)	♥	.heat_output_secondary	Heating Capacity Secondary Status
	nvoUnitStatus (bytes 6-7)	♥	.cool_output	Cooling Capacity Status
	nvoUnitStatus (bytes 8-9)	♥	.econ_output	Economizer Status
	nvoUnitStatus (bytes 10-11)	♥	.fan_output	Supply Fan Speed Status
	nvoUnitStatus (byte 12)	♥	.in_alarm	In Alarm
147	nvoUnitVoltage	♥	UNVT_3Phase_volt	Unit Voltage
	nvoUnitVoltage (bytes 1-2)	♥	SNVT_volt_ac	Voltage AB
	nvoUnitVoltage (bytes 3-4)	♥	SNVT_volt_ac	Voltage BC
	nvoUnitVoltage (bytes 5-6)	♥	SNVT_volt_ac	Voltage CA

Note: Grayed out LONtalk network variables are not supported.

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	SNVT	Variable Description
0	nciBldgStaticSP	SNVT_press_p	Space Static Pressure Setpoint
1	nciBypassTime	SNVT_time_min	Occupied Bypass Time
2	nciCabinetStyle	UCPT_cabinet_style	Cabinet Style ^(a)
3	nciCool	UCPT_cool_type	Cool Type ^(a)
4	nciCoolResetEn	SNVT_switch	Cooling Reset Type Status
5	nciCRC	UCPT_crc	Manufacturer-defined ^(a)
6	nciDACISP	SNVT_temp_p	Discharge Air Cooling Setpoint
7	nciDADewpointSP	SNVT_temp_p	Discharge Air Dewpoint Setpoint
8	nciDAHTSP	SNVT_temp_p	Discharge Air Heating Setpoint
9	nciDAREheatSP	SNVT_temp_p	Discharge Air Reheat Setpoint
10	nciDaytime	SNVT_temp_p	Daytime Warmup Initiation Setpoint
11	nciDevBuildNum	U16	Device Build Number
12	nciDeviceConfig	UCPTdeviceConfig	Manufacturer-defined ^(a)
13	nciDevMajVer	SCPTdevMajVer	Software Major Version
14	nciDevMinVer	SCPTdevMinVer	Software Minor Version
15	nciDuctStatSP	SNVT_press_p	Duct Static Pressure Setpoint
16	nciEconConfigTyp	UCPT_econo_config_type	Economizer Decision Method ^(a)
17	nciEconVent	UCPT_OA_type	Economizer Type Identifier ^(a)
18	nciERFrostAvodSP	UCPT_ERFrostAvoidSP	Energy Recovery Frost Avoidance Temp Setpoint ^(a)
19	nciExhRet	UCPT_ER_type	Exhaust Or Return Fan Type ^(a)
20	nciExhStartPos	SNVT_lev_percent	Exhaust Enable Position Setpoint
21	nciHeatResetEn	SNVT_switch	Heating Reset Type Status
22	nciHvacType	SNVT_hvac_type	HVAC Unit Type Identifier
23	nciLocation	SNVT_str_asc	Location Label
24	nciMinOAFflowSP	SNVT_flow	Outdoor Air Minimum Flow Setpoint
25	nciMinOutTm	SNVT_time_sec	Minimum Send Time
26	nciOAEnthSP	SNVT_enthalpy	Economizer Outdoor Air Enthalpy Enable Setpoint
27	nciOAMinPos	SNVT_lev_percent	Outdoor Air Damper Minimum Position
28	nciOATSP	SNVT_temp_p	Economizer Enable Minimum Outdoor Air Temperature Setpoint
29	nciPreheat	UCPT_heat_type	Preheat Type Identifier ^(a)
30	nciRcvHrtBt	SNVT_time_sec	Receive Heartbeat
31	nciReheat	UCPT_heat_type	Reheat Type Identifier ^(a)

Symbio™ 700 Integration Points List
LonTalk®
Precedent® and Axiom™ Rooftop WSHP

Date: 11/08/2024
 Firmware Release: V7.00.0011
 Reference Document: BAS-SVP086*-EN



NV #	Network Variable Name	SNVT	Variable Description
32	nciRetFanPressSP	SNVT_press_p	Return Fan Air Pressure Setpoint
33	nciRefrigType	UCPT_refrig_type	Refrigeration Type Identifier ^(a)
34	nciSetpoints	SNVT_temp_setpt	Occupancy Temperature Setpoints Occupied Cool Setpoint Occupied Standby Cooling Setpoint Unoccupied Cooling Setpoint Occupied Heating Setpoint Occupied Standby Heating Setpoint Unoccupied Heating Setpoint
35	nciSndHrtBt	SNVT_time_sec	Send Heartbeat Time
36	nciSpaceCO2Lim	SNVT_ppm Space	CO2 High Limit
37	nciSpaceCO2LowLm	SNVT_ppm	Space CO2 Low Limit ^(a)
38	nciSpaceDehumSP	SNVT_lev_percent	Space Dehumidification Setpoint
39	nciSpaceHumSP	SNVT_lev_percent	Space Humidification Setpoint
40	nciSupplyFan	UCPT_fan_type	Supply Fan Type Identifier ^(a)
41	nciUntryType	UCPT_large equip_type	Unitary Type Identifier ^(a) Model Information Cooling Source Size Heating Source Size Number of Circuits Number of Compressors, Circuit 1 Number of Compressors, Circuit 2

^(a) Manufacturer defined.

Note: Grayed out LONtalk network variables are not supported.