



REF DES	LEGEND	LINE NO
CFS	SWITCH - CLOGGED FILTER	349
ECA	ACTUATOR - ECONOMIZER, LOW LEAK	326
ECA	ACTUATOR - ECONOMIZER	321
FOM	MODULE - FRESH AIR OPTIONS	312
OAH	SENSOR - OUTDOOR AIR HUMIDITY	313
RAH	SENSOR - RETURN AIR HUMIDITY	309
RASD	SENSOR - RETURN AIR SMOKE DETECTOR	305
RAT	SENSOR - RETURN AIR TEMP	317
WCI	MODULE - WIRELESS COMMUNICATIONS	306
XFR	CONTACTOR - POWER EXHAUST	316



- 1 FRESH AIR OPTIONS MODULE ONLY PRESENT ON CERTAIN UNIT CONFIGURATIONS. SEE INSET "A" FOR UNITS WITHOUT FRESH AIR OPTIONS MODULE
- 2 RETURN AIR TEMP SENSOR PRESENT ON UNITS WITH DIFFERENTIAL DRY BULB, REFERENCE ENTHALPY, AND COMPARATIVE ENTHALPY CONTROL
- 3 OUTDOOR AIR HUMIDITY SENSOR PRESENT ON UNITS WITH REFERENCE ENTHALPY AND COMPARATIVE ENTHALPY CONTROL
- 4 RETURN AIR HUMIDITY SENSOR PRESENT ON UNITS COMPARATIVE ENTHALPY CONTROL

DESIGNER:	A. WAEDEL
ENGINEER:	B. JONES
TRANE © DATE:	29-SEP-2021
REPLACES:	
SIMILAR TO:	
REVISION DATE:	22-NOV-2021
REVISED BY:	R. JOHNSON
APPROVED BY:	D. MACVICAR
CAD SYSTEM USED:	CREO SCHEMATICS

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

PRECEDENT
UNIT SCHEMATIC
SCHEMATIC; SHEET 6
CONTROLS
FRESH AIR OPTIONS

MASTER NUMBER:

DRAWING NUMBER:
12134438

SHEET:
6 OF 10

REV
C