




LEGEND		
REF DES	DESCRIPTION	LINE NO
AB	ADAPTER BOARD	201
CC1	CONTACTOR - COMPRESSOR 1	188
CC1 (AUX2)	CONTACTOR - COMPRESSOR 1 AUX 2	185
CC2	CONTACTOR - COMPRESSOR 2	195
CC2 (AUX2)	CONTACTOR - COMPRESSOR 2 AUX 2	187
CUS2	SOLENOID - CMR 2 UNLOADING	215
DTL1	SWITCH - DISCHARGE TEMP LIMIT 1	204
DTL2	SWITCH - DISCHARGE TEMP LIMIT 2	210
FRS1	SWITCH - FREEZESTAT 1	188
FRS2	SWITCH - FREEZESTAT 2	195
HPC1	SWITCH - HIGH PRESSURE CUT OUT 1	201
HPC2	SWITCH - HIGH PRESSURE CUT OUT 2	207
TD1	RELAY - TIME DELAY	184
TD2	RELAY - TIME DELAY	192
VHR	RELAY - VENTILATION HEAT	194
VHR-NC	CONTACT, NORMALLY CLOSED, VHR	191
VHR-NO	CONTACT, NORMALLY OPEN, VHR	189
VHR-TB	TERMINAL BLOCK - VENTILATION HEAT	185

NOTES: (STANDARD NOTES 1-3, WIRE COLOR & SYMBOL LEGEND TABLES APPLY TO ALL SHEETS.)

- 1 SEE LOW AMBIENT SCHEMATIC FOR BALANCE OF CIRCUIT.
- 2 CONNECT CUSTOMER SUPPLIED DEVICE TO VHR-TB FOR VENTILATION HEAT OPERATION. VHR RELAY IS ACTIVE WHEN UNIT IS IN HEAT MODE. ELECTRICAL RATING FOR VHR CONTACTS: 3A @ 277VAC

DESIGNER: T.PEED
ENGINEER: R. CERVANTES
TRANE © DATE: 7/11/2022
REPLACES:
SIMILAR TO:
REVISION DATE: 7/25/2024
REVISED BY: C. COLLINS
APPROVED BY:
CAD SYSTEM USED: CREO SCHEMATICS

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

PRECEDENT
UNIT SCHEMATIC

SCHEMATIC; SHEET 4, CONTROLS, ADAPTER BOARD UNIT CONTROLS, DUAL COMPRESSOR WSHP

MASTER NUMBER: DRAWING NUMBER: SHEET: REV
12134550 **4** **C**