

LEGEND		
REF DES	DESCRIPTION	LINE NO
CCM	MODULE - CUSTOMER CONNECTIONS	373
COF	CONDENSATE OVERFLOW SWITCH	397
FFS	FAN FAIL SWITCH	374
HST	HUMIDSTAT	410
OAH	SENSOR - OUTDOOR AIR HUMIDITY	374
RMP	REMOTE MIN POSITION	412

NOTES: (SEE SHEET 1 FOR STANDARD NOTES 1-3, WIRE COLOR & SYMBOL LEGEND TABLES.)

- 1

ALL FIELD WIRING REPRESENTED BY DASHED LINES SHALL BE CLASS 2.
- 2

TO SHUT DOWN UNIT FOR EXTERNAL AUTO-STOP, CONNECT FIELD SUPPLIED CONTROL DEVICE ACROSS PINS 3&4. UNIT STOPS WHEN SWITCH CLOSSES.
- 3

TO ENABLE VENTILATION OVERRIDE, CONNECT FIELD SUPPLIED CONTROL DEVICE ACROSS PINS:
5 & 6: PRESSURE
7 & 8: PURGE
9 & 10: EXHAUST
FUNCTION ENABLED WHEN SWITCH CLOSSES ADD ELECTRICAL INFORMATION FOR CIRCUIT.
- 4

WHEN OPTIONAL REMOTE MINIMUM POSITION POTENTIOMETER IS REQUIRED, WIRE AS SHOWN.
- 5

WIRING SHOWN FOR OPTIONAL ALARM INDICATOR OUTPUT. ADD ELECTRICAL INFORMATION FOR CIRCUIT.
- 6

FIELD INSTALLED HUMIDISTAT REQUIRED ON UNITS WITH HOT GAS REHEAT.

CUSTOMER CONNECTIONS MODULE
(CCM)

ADDRESS 1
GND
ADDRESS 2
GND
ADDRESS 3
GND
ADDRESS 4
GND

OPTIONAL CUSTOMER CONNECTIONS MODULE IN
STANDARD EFFICIENCY UNITS

DESIGNER: YASHRAJ.N.M
ENGINEER: D. MACVICAR
TRANE © DATE: 18-DEC-2023
REPLACES: --
SIMILAR TO: --
REVISION DATE: 12-MAR-2024
REVISED BY: E.STOVALL
APPROVED BY: N.CHALITA
CAD SYSTEM USED: CREO SCHEMATICS

TRANE®

THIS DRAWING IS PROPRIETARY
AND SHALL NOT BE COPIED OR
ITS CONTENTS DISCLOSED TO
OUTSIDE PARTIES WITHOUT THE
WRITTEN CONSENT OF TRANE.

PRECEDENT
UNIT SCHEMATIC, SHEET 7
CONTROLS, CUSTOMER CONNECTION OPTIONS, A CAB

MASTER NUMBER:

DRAWING NUMBER:

SHEET:

REV

12134810

7

B