


SYMBIO 700
(UC)

- 1 ALL FIELD WIRING REPRESENTED BY DASHED LINES SHALL BE CLASS 2.
- 2 TO SHUT DOWN UNIT FOR EMERGENCY STOP, CONNECT FIELD SUPPLIED CONTROL DEVICE ACROSS PINS 1 & 2. UNIT STOPS WHEN SWITCH CLOSSES.
- 3 WIRING SHOWN FOR HOT GAS REHEAT UNITS.



THIS DRAWING IS PROPRIETARY
AND SHALL NOT BE COPIED OR
ITS CONTENTS DISCLOSED TO
OUTSIDE PARTIES WITHOUT THE
WRITTEN CONSENT OF TRANE.

MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
--	12135031	3	B