


LEGEND	
DEVICE DESIGNATION	DESCRIPTION
3F20	FUSEBLOCK
3KF25	QUAD - HEAT RELAY #1
3QA25	CONTACTOR - PRIMARY
3QA26	CONTACTOR - PRIMARY
3QA31	CONTACTOR - BACK-UP
3XD16	TERMINAL BLOCK - 115V
3XD17	TERMINAL BLOCK - 115V COM
3XD5	TERMINAL BLOCK

CLASS T FUSE REPLACEMENT TABLE		
KW	VOLTAGE	FUSE
30	480	50
	600	40



DESIGNER:	D. CONDIE
ENGINEER:	R. ROBINSON
TRANE © DATE:	08-JUN-18
REPLACES:	--
SIMILAR TO:	--
REVISION DATE:	--
REVISED BY:	--
APPROVED BY:	--
CAD SYSTEM USED:	PRO/DIAGRAM

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

IEC DESIGN COMPLIANT

INTELLIPAK DIAGRAM			
COMPONENT LAYOUT - ELECTRIC HEAT PANEL 30KW - 480V/600V			
MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
	12132849	1 OF 1	A