


661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720



WIRE COLOR ABBREVIATION CODES			
CODE	COLOR	CODE	COLOR
BK	BLACK	PK	PINK
BL	BLUE	R	RED
BR	BROWN	TQ	TURQUOISE
G	GREEN	V.(PR)	PURPLE
GY	GREY	W	WHITE
O	ORANGE	Y	YELLOW

LOCATION CODE	
LOC#	ZONE
1	CONTROL PANEL
2	CONDENSER ZONE
3	HEAT/EXT CASING
4	SUPPLY FAN ZONE
5	EVAP/FILTERS
6	RETURN AIR ZONE
7	CUSTOMER PROVIDED

CAUTION

USE COPPER CONDUCTORS ONLY!

UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.

FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

ATTENTION

N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!

LES BORNES DE L'UNIT É NÉ SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.



L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.

PRECAUCIÓN

¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!

LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.

SI NO LO HACE. PUEDE OCASIONAR DAÑO AL EQUIPO.



LEGEND		
REF DES	DESCRIPTION	LINE NO
3E6	UNSET	672, 674, 677
3F20	FUSEBLOCK - BRANCH CIRCUIT #1	672
3F21	FUSEBLOCK - BRANCH CIRCUIT #2	675
3F22	FUSEBLOCK - BRANCH CIRCUIT #3	677
3K2	RELAY - HEAT FAIL	692, 703
3K4	RELAY - DUAL POINT POWER PROVING	671, 704
3KF31	LLID (QUAD) - HEAT CONTROLS	705
3KF39	LLID (HEX) - HEAT FAIL SIGNAL	702
3QA25	UNSET	672, 705
3QA26	UNSET	675, 707
3QA27	UNSET	677, 710
3QA31	CONTACTOR - BACKUP #1	672, 673, 675, 694, 695
3QA32	CONTACTOR - BACKUP #2	675, 677, 678, 695
3QB4/3XD5	ELECTRIC HEAT DISCONNECT / TERMINAL BLOCK	666
3S10	SWITCH - TEMP (MANUAL RESET)	694
3S11	SWITCH - TEMP (AUTO RESET #1)	701
3S12	SWITCH - TEMP (AUTO RESET #2)	701
3XD16	TERMINAL BLOCK - 115VAC	716
3XD17	TERMINAL BLOCK - 115VAC COMMON	716

- NOTES:
- 1 3K4 RELAY IS USED WITH 200/230V UNITS TO VERIFY SEPARATE POWER SOURCE IS TURNED ON.
 - 2 WIRING SHOWN FOR 380-575VAC UNITS. SEE INSET A AND INSET B FOR 200-230VAC UNITS.
 - 3 HEATING ELEMENTS ARE SHOWN DELTA CONNECTED, BUT MAY BE WYE CONNECTED.

DESIGNER:	A. WAELDE
ENGINEER:	S. MCKINLEY
TRANE © DATE:	5-FEB-2022
REPLACES:	
SIMILAR TO:	
REVISION DATE:	5-FEB-2022
REVISED BY:	A. WAELDE
APPROVED BY:	S. MCKINLEY
CAD SYSTEM USED:	CREO SCHEMATICS

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

IPAK 1 SCHEMATIC ELECTRIC HEAT 3 CIRCUIT

MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
	12134381	12 OF 17	B