





601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660



LEGEND		
REF DES	DESCRIPTION	LINE NO
4BT2	SENSOR - SUPPLY AIR TEMP	635
5BM1	SENSOR - OUTDOOR AIR HUMIDITY	605
5BT4	SENSOR - SUCTION TEMP CKT 1 TEMP 1	629
5BT5	SENSOR - SUCTION TEMP CKT 1 TEMP 2	630
5BT6	SENSOR - SUCTION TEMP CKT 2 TEMP 1	632
5BT7	SENSOR - SUCTION TEMP CKT 2 TEMP 2	633
5BT8	SENSOR - MIXED AIR TEMP	653
5BT9	SENSOR - LEAVING EVAP AIR TEMP	621
5MB11	ACTUATOR - OUTDOOR AIR BYPASS	616
5QM1	SENSOR- EXV CKT 1 VALVE 1	622
5QM2	SENSOR- EXV CKT 1 VALVE 2	624
5QM3	SENSOR- EXV CKT 2 VALVE 1	626
5QM4	SENSOR- EXV CKT 2 VALVE 2	627
6BM2	SENSOR - RETURN AIR HUMIDITY	603
6BT3	SENSOR - RETURN AIR TEMP	637
6BT16	SENSOR - ERW LEAVING WHEEL AIR TEMP	639
6KF20	LLID (HEX) - ERW & HUMIDITY	601
6KF21	LLID (HEX) - FILTER STATUS #1	657
6MB12	DAMPER - RELIEF BYPASS	611
6TA4	POWER SUPPLY #4 - RETURN SECTION	632
6TF10	TRANSDUCER - PRE FINAL FILTER PRESSURE	649



DESIGNER: A. WAELE
ENGINEER: E. CAROTA
TRANE © DATE: 29-SEP-2022
REPLACES:
SIMILAR TO:
REVISION DATE: 18-OCT-2022
REVISED BY: A. WAELE
APPROVED BY: E. CAROTA
CAD SYSTEM USED: CREO SCHEMATICS

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

IPAK 2
CONTROLS SCHEMATIC
90-150T AIR HANDLER CONTROLS #3

MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
	12134647	11 OF 17	B