


LEGEND		LINE NO
REF DES	DESCRIPTION	
ECA	ACTUATOR - ECONOMIZER	321
FAOM	MODULE - FRESH AIR OPTIONS	312
OAH	SENSOR - OUTDOOR AIR HUMIDITY	313
RAH	SENSOR - RETURN AIR HUMIDITY	309
RAT	SENSOR - RETURN AIR TEMP	317
XFR	CONTACTOR - POWER EXHAUST	316



NOTES: (SEE SHEET 1 FOR STANDARD NOTES 1-3, WIRE COLOR & SYMBOL LEGEND TABLES.)

- 1 FRESH AIR OPTIONS MODULE PRESENT ON CERTAIN UNIT CONFIGURATIONS.
- 2 RETURN AIR TEMP SENSOR PRESENT ON UNITS WITH DIFFERENTIAL DRY BULB, COMPARATIVE ENTHALPY CONTROL
- 3 OUTDOOR AIR HUMIDITY SENSOR PRESENT ON UNITS WITH REFERENCE ENTHALPY AND COMPARATIVE ENTHALPY CONTROL
- 4 RETURN AIR HUMIDITY SENSOR PRESENT ON UNITS WITH COMPARATIVE ENTHALPY CONTROL

DESIGNER: SUDHEER KUMAR	TRANE ®	FOUNDATION UNIT SCHEMATIC; SHEET 6, CONTROLS FRESH AIR OPTIONS			
ENGINEER: VENKATESH.K					
TRANE © DATE: 03-OCT-2023					
REPLACES:					
SIMILAR TO:	THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.	MASTER NUMBER:	DRAWING NUMBER: 12134910	SHEET: 6	REV B
REVISION DATE: 04-JUL-2024					
REVISED BY: MOHAMMAD S					
APPROVED BY: VENKATESH.K					
CAD SYSTEM USED: CREO SCHEMATICS					