





WITH SUPPLY VFD BYPASS ONLY



NOTES:

1. SOME COMPONENTS SHOWN ARE OPTIONAL AND MAY NOT BE PRESENT. SEE UNIT SCHEMATIC FOR OPTIONAL UNIT CONFIGURATION.

	SUPPLY VFD BYPASS PANEL - SUPPLY VFD W/ BYPASS, CLASS J - FAST ACTING								
	4F15 AND 4F16 (x3 EA)								
	VOLTAGE	3HP	6HP	10HP	15HP	20HP	30HP	40HP	50HP
4-POLE	200V	10A	25A	50A	80A	80A	100A	N/A	N/A
	230V	10A	25A	25A	50A	80A	80A	N/A	N/A
	460V	10A	15A	15A	25A	25A	50A	50A	80A
	575V	20A	20A	20A	20A	20A	30A	30A	80A
	200V	10A	25A	50A	80A	80A	100A	N/A	N/A
6-POLE	230V	10A	25A	25A	50A	80A	80A	N/A	N/A
	460V	10A	15A	15A	25A	50A	50A	50A	N/A
	575V	20A	20A	20A	20A	30A	30A	80A	N/A

LEGEND	
DEVICE DESIG	DESCRIPTION
4TB1	SUPPLY FAN VFD #1
4TB2	SUPPLY FAN VFD #2
4F15	FUSEBLOCK - SUPPLY VFD #1 BYPASS
4F16	FUSEBLOCK - SUPPLY VFD #2 BYPASS
4FC1	OVERLOAD SUPPLY FAN #1
4FC2	OVERLOAD SUPPLY FAN #2
4QA19	CONTACTOR - SUPPLY BYPASS VFD #1
4QA20	CONTACTOR - SUPPLY BYPASS VFD #2
4QA21	CONTACTOR - SUPPLY VFD RUN #1
4QA22	CONTACTOR - SUPPLY VFD RUN #2

DESIGNER:	N. PATAGUE
ENGINEER:	E. CAROTA
TRANE © DATE:	3/22/2024
REPLACES:	--
SIMILAR TO:	--
REVISION DATE:	4/15/2024
REVISED BY:	J. HENRICKSEN
APPROVED BY:	E. CAROTA
CAD SYSTEM USED:	CREO PARAMETRIC

TRANE®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

INTELLIPAK DIAGRAM			
COMPONENT LAYOUT - SUPPLY VFD PANEL			
MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
	12135010	1 OF 1	B