
RELEASED 21/Oct/2026 13:35:52 GMT



	CONDUCTOR COLOR TABLE	
CONDUCTOR POSITION	CONDUCTOR BASE COLOR	CONDUCTOR TRACER COLOR
1	BLACK	
2	RED	
3	BLUE	
4	ORANGE	
5	YELLOW	
6	BROWN	
7	RED	BLACK
8	BLUE	BLACK
9	ORANGE	BLACK
10	YELLOW	BLACK
11	BROWN	BLACK
12	BLACK	RED
13	BLUE	RED
14	ORANGE	RED
15	YELLOW	RED
16	BROWN	RED
17	BLACK	BLUE
18	RED	BLUE
19	ORANGE	BLUE
20	YELLOW	BLUE
21	BROWN	BLUE
22	BLACK	ORANGE
23	RED	ORANGE
24	BLUE	ORANGE
25	YELLOW	ORANGE
26	BROWN	ORANGE

NOTES: (SEE SHEET 1 FOR STANDARD NOTES 1-3 & WIRE COLOR TABLE)

1. ALL FIELD WIRING REPRESENTED BY DASHED LINES SHALL BE CLASS 2.
2. TO SHUT DOWN UNIT FOR EMERGENCY STOP, CONNECT FIELD SUPPLIED CONTROL DEVICE ACROSS PINS 1 & 2. UNIT STOPS WHEN SWITCH CLOSES.
3. WIRING SHOWN FOR UNITS WITH GAS HEAT OR COOLING ONLY UNITS WITHOUT ELECTRIC HEAT. SEE INSET A FOR UNITS WITH ELECTRIC HEAT.
4. SEE APPLICABLE SCHEMATIC/COMPONENT LOCATION DIAGRAM FOR ELECTRIC HEAT FOR BALANCE OF CIRCUIT WHEN OPTIONAL ELECTRIC HEAT IS REQUIRED.
5. OPTIONAL LEAK DETECTION SENSOR PRESENT ON 4T/5T HOT GAS REHEAT ONLY.
6. WIRING SHOWN FOR STANDARD EFFICIENCY UNITS, SEE INSET B FOR HIGH EFFICIENCY UNITS.
7. WIRING SHOWN FOR HOT GAS REHEAT UNITS.
8. WIRING SHOWN FOR UNITS WITH UNIT MOUNTED DISCHARGE TEMPERATURE SENSOR. SEE INSET C FOR UNITS WITH REMOTE DUCT MOUNTED DISCHARGE AIR TEMPERATURE SENSOR.

	LEGEND	
REF DES	DESCRIPTION	LINE NO
DTS1	SENSOR- DISCHARGE TEMPERATURE UNIT MOUNTED	129
DTS2	SENSOR-DISCHARGE TEMPERATURE DUCT MOUNTED	164
DTS-TB	DISCHARGE TEMPERATURE SENSOR TERMINAL BLOCK	160
FOS	SWITCH- FROSTAT	129
LCI	MODULE-LCI	129
LPC1	SWITCH - LOW PRESSURE 1	157
OAS	SENSOR - OUTDOOR AIR	129
SHS	SENSOR - SPACE HUMIDITY	177
UC	MODULE - UNIT CONTROLLER	143

SYMBOL LEGEND

TRANE WIRING:	CUSTOMER PROVIDED:	EARTH GROUND:	SPLICE:	MULTIPLE WIRE SYMBOL:	SHIELDED CABLE:
FIELD WIRING:	ALTERNATE/OPTIONS:	EQUIPMENT CHASSIS:	JUNCTION:	TWISTED CONDUCTORS:	LINE BREAK:

TRANE ®

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.

PRECEDENT
UNIT SCHEMATIC; SHEET 3, CONTROLS
SYMBIO 700

DESIGNER:	ENGINEER:	NUMBER:	TRANE © DATE:	REV	SHEET
RAKESH N	ARAVINDH K	12135109	26-AUG-2026	B	3