



- INSET "E" GENERIC THERMISTOR

GND J4-2

U1P2 J4-1

7RT4

OAT OR FIELD RECONFIG'D
AS GENERIC THERMISTOR

INSET "F" ZONE HUMIDITY SENSOR

U1P1 J4-4

24VAC J4-3

6U8

INSET "G" TWO POSITION DAMPER

2L2 M

20M

24VAC J18-1

GND J18-2

30B

OPEN J18-3

CLOSE J18-4

WHT PLG & CAP

INSET "H" ECONOMIZER DAMPER LEFT HAND

2L2 M

20M (YEL)

24VAC J18-1

GND J18-2

30B (PNK)

OPEN J18-3

CLOSE J18-4

21E (BLU)

TR1

CCW

CW

24B (BRN)

LEGEND		
DEVICE DESIGNATION	DESCRIPTION	LINE NUMBER
1U1	UC400—B MODULE	74
1U3	ECM ENGINE BOARD	106
2U3	WIRELESS COM INTERFACE	85
3L1	COOLING/ CHANGEOVER VALVE	90,119,122
7L1	COOLING/ CHANGEOVER VALVE	90,119,122
3L2	HEATING COIL VALVE	94,126,128
7L2	HEATING COIL VALVE	94,126,128
5RT5	DISCHARGE AIR TEMP SNSR	91
7U1	CO2 SENSOR	93
3S8	CONDENSATE OVERFLOW SWITCH	96
4RT4	OUTSIDE AIR TEMP SENSOR	97
1S9	FREEZE—STAT	98
3RT1	AUTOCHG TEMP SENSOR\ EH LO	100
2L2	ECON DMPR RH/LH, DMPR ACTUATOR	108,120,127
7RT4	GENERIC THERMISTOR	113
6U8	ZONE HUMIDITY SENSOR	116

REVIEWS	TRANE		REV
REVISION DATE	3518-6105		
DRAWN BY P. ASHURST	SCHEMATIC FAN COIL / GEORGE-FLO UNDO-8 STANDARD COIL		
DATE 3 JUN 2019	SIMILAR TO ② SAME		