

TRANE

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE
COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE
PARTIES WITHOUT THE CONSENT OF TRANE.

DRAWN BY: M.FRITZ TRANE© DATE: 01/04/2019
REPLACES: 4367-0370 REVISION DATE: --
CAD SYSTEM USED: Pro/DIAGRAM SIMILAR TO: --

FILE NUMBER: DRAWING NUMBER: 43675762 SHEET: 1 OF 1 REV A

ODYSSEY

DIAGRAM

SCHEMATIC/CONNECTION
11.25/14.96KW ELECTRIC HEAT
208-240V 3PH

MATERIAL:


MAC-TAC MR1 LABEL MATERIAL (WHITE IN COLOR)
WITH L23 L50 ADHESIVE LINER.

ALTERNATE MATERIAL:

FLEXCON VINYL V400 HW TC-160 LABEL MATERIAL
(WHITE IN COLOR) WITH V-23 90 PFW ADHESIVE LINER.

NOTES:
ALL PRINTING TO BE BLACK

SIZE:
8.25 X 10.00




LEGEND		
DEVICE DESIGN	DESCRIPTION	LINE NUMBER
AH	CONTACTOR - HEATER	2,3,4,8
CN-1	CONNECTOR - WIRE NUT #1	5
CN-2	CONNECTOR - WIRE NUT #2	6
CN-3	CONNECTOR - WIRE NUT #3	7
F	CONTACTOR - INDOOR FAN	11,12,13
HTRA	HEATER RACK	2
HTRB	HEATER RACK	5
LTB2	TERMINAL BLOCK - LOW VOLTAGE	14,16
TCOA	SWITCH - TEMP LIMIT	8

AH - 2,3,4,8 (8)

ELECTRICAL RATING			
240 VOLTS		208 VOLTS	
KW	AMPS	KW	AMPS
14.96	36	11.25	31.2

WIRE COLORS	
ABBR	COLOR
BK	BLACK
BR	BROWN
R	RED
YL	YELLOW
OR	ORANGE

CAUTION	PRECAUCIÓN	ATTENTION
USE COPPER CONDUCTORS ONLY!	N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!	UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!
UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.	LES BORNES DE L'UNITÉ NE SONT PAS CONçUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.	LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.
FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.	L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.	SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.



NOTES:

- 1. FIELD CONNECT CONTROL LEADS AS SHOWN: 137B(BK) - LTB2-1 (FIRST STAGE HEAT) 135B(BR) - LTB2-2 (HEATER/FAN INTERLOCK)
- 2. WHEN USING SINGLE POINT POWER ENTRY THROUGH ELECTRIC HEAT CONTROL BOX, REMOVE CONNECTORS CN-1 AND CN-2 AND CN-3 FROM THE END OF WIRES 31A(R) AND 32A(R) AND 33A(R) THEN TERMINATE THEM INTO BOX LUGS LOCATED ON THE BOTTOM OF THE INDOOR FAN CONTACTOR IN THE AIR HANDLER CONTROL BOX. SEE THE ELECTRIC HEAT INSTALLER'S GUIDE FOR INSTALLATION INSTRUCTIONS.
- 4. UNLESS OTHERWISE NOTED, ALL SWITCHES ARE SHOWN AT 25°C (77°F) AT ATMOSPHERIC PRESSURE, AT 50% RELATIVE HUMIDITY WITH ALL UTILITIES TURNED OFF AND AFTER A NORMAL SHUTDOWN HAS OCCURRED.
- 7. DASHED LINES INDICATE RECOMMENDED FIELD WIRING BY OTHERS. DASHED LINE ENCLOSURES AND/OR DASHED DEVICE OUTLINES INDICATE COMPONENTS PROVIDED BY THE FIELD. PHANTOM LINE ENCLOSURES INDICATE ALTERNATE CIRCUITRY OR AVAILABLE SALES OPTIONS.
- 8. NUMBERS ALONG THE RIGHT SIDE OF THE SCHEMATIC DESIGNATE THE LOCATION OF CONTACTS BY THE LINE NUMBER. AN UNDERLINED NUMBER INDICATES A NORMALLY CLOSED CONTACT.