


















DEVICE PREFIX LOCATION CODE	
AREA	LOCATION
1	MAIN CONTROL PANEL
2	SUPPLY FAN AND COIL SECTION
3	
4	
5	EXTERNAL PIPING
6	ELECTRIC HEAT CONTROL BOX
7	FIELD INSTALLED DEVICE

LEGEND		
DEVICE DESIGNATION	DESCRIPTION	LINE NUMBER
1U2	ADAPTER BOARD	88,81
1U4	ENGINE BOARD	84,118
2S3	EL HT LOCKOUT SWITCH	75,105
6K6	CONTACTOR; EL HT STG 1	107,77
6S8	EL HT HIGH TEMP	108,77
6K7	CONTACTOR; EL HT STG 2	109
1K2	CONTACTOR; EL HT	107,77
1K3	CONTACTOR; EL HT	109
1K6	RELAY; FAN STATUS	82,83
5L1	COOLING COIL VALVE MOTOR	84,115
5L2	HEATING COIL VALVE MOTOR	89,119
7L1	COOLING COIL VALVE MOTOR	115,84
7L2	HEATING COIL VALVE MOTOR	89,119
2S1	CONDENSATE OVERFLOW SWITCH	126
2S2	FREEZESTAT	128
7L3	MIXING BOX DAMPER ACTUATOR	125
7L4	OUTSIDE AIR DAMPER ACTUATOR	125,128
4L1	MIXING BOX DAMPER ACTUATOR	133
5RT1	ENTERING WATER TEMP SENSOR	124

REVISED DATE	TRAINING BY	DATE	23 FEB 2018
THIS DRAWING IS UNCLASSIFIED AND IS NOT TO BE CONTROLED BY THE NATIONAL SECURITY AGENCY (NSA/CSS) OR THE STATE DEPARTMENT (STATE). IT IS THE PROPERTY OF THE NSA/CSS AND IS TO BE RETURNED TO THE NSA/CSS WHEN REQUESTED.			
TRANE		5026-1697	
SCHEMATIC DIAGRAM		BCXD	
CSST		STANDARD COILS	