

- NOTES:
1. DASHED LINES INDICATE RECOMMENDED FIELD WIRING BY OTHERS. DASHED LINE ENCLOSURES AND/OR DASHED DEVICE OUTLINES INDICATE COMPONENTS PROVIDED BY THE FIELD. PHANTOM LINE ENCLOSURES INDICATE ALTERNATE CIRCUITRY OR AVAILABLE SALES OPTIONS. SOLID LINE INDICATES WIRING BY TRANE CO.
 2. CONNECTIONS SHOWN ARE FOR 230V/380V/575V/60HZ/3PH OR 380V-415V/50HZ/3PH. WHEN 208V/460V/60HZ/3PH OPERATION IS REQUIRED, MOVE WIRE 1C(R) FROM 230V/380V/575V/60HZ/3PH OR 380V-415V/50HZ/3PH TERMINAL OF TNS1 TO 208V/460V/60HZ/3PH TERMINAL.
 3. CAUTION: DO NOT JUMPER ACROSS SWITCHES DTL1, DTL2, LPC1, HPC1 AND HPC2 UNDER ANY CIRCUMSTANCES.
 4. NOTICE: DO NOT OPERATE OR APPLY POWER TO COMPRESSORS WHILE UNDER A VACUUM. FAILURE TO FOLLOW THESE INSTRUCTIONS WILL RESULT IN COMPRESSOR FAILURE.
 5. IF EVAPORATOR DEFROST CONTROL (EDC) IS USED ON INDOOR UNIT, REMOVE JUMPER WIRE W3(BL) BETWEEN TERMINALS "B1" AND "B2" ON LT81.

TRANE		FILE NUMBER:	DRAWING NUMBER:	SHEET:	REV
THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE CONSENT OF TRANE.			12131681	1 OF 1	A
DRAWN BY:	TRANE DATE:	ODYSSEY DIAGRAM CONNECTION - CONDENSER 1ST MANIFOLDED (ALL VOLTAGES), 20T & 25T MANIFOLDED 380/460/575V/60HZ / 380-415V/50HZ			
D. MCCAULEY	7 JUL 15				
REPLACES:	REVISION DATE:				
--	--				
CAD SYSTEM USED:	SIMILAR TO:				
Pro/DETAIL	--				

WIRE COLOR DESIGNATION			
ABBR	COLOR	ABBR	COLOR
BL	BLUE	O	ORANGE
BK	BLACK	R	RED
BR	BROWN	V	VIOLET (PURPLE)
G	GREEN	W	WHITE
GY	GRAY (SLATE)	Y	YELLOW

