



1 —
2 —
3 —
4 —
5 —
6 —
7 —
8 —
9 —
10 —
11 —
12 —
13 —
14 —
15 —
16 —
17 —
18 —
19 —
20 —
21 —
22 —
23 —
24 —
25 —
26 —
27 —
28 —
29 —
30 —
31 —
32 —
33 —
34 —
35 —
36 —
37 —
38 —
39 —
40 —
41 —
42 —
43 —
44 —
45 —
46 —
47 —
48 —
49 —
50 —
51 —
52 —
53 —
54 —
55 —
56 —
57 —
58 —
59 —
60 —



4 TO 1KF1 (MODBUS) MAIN CONTROL PANEL

4 TO 1XP50 MAIN CONTROL PANEL



- NOTES:
- UNLESS OTHERWISE NOTED, ALL SWITCHES ARE SHOWN AT 25° C (77° F), AT ATMOSPHERIC PRESSURE, AT 50% RELATIVE HUMIDITY, WITH ALL UTILITIES TURNED OFF, AND AFTER A NORMAL SHUTDOWN HAS OCCURRED.
 - DASHED LINES INDICATE RECOMMENDED FIELD WIRING BY OTHERS. DASHED LINE ENCLOSURES AND/OR DASHED DEVICE OUTLINES INDICATE COMPONENTS PROVIDED BY THE FIELD. PHANTOM LINE ENCLOSURES INDICATE ALTERNATE CIRCUITRY OR AVAILABLE SALES OPTIONS. SOLID LINE INDICATES WIRING BY TRANE CO.
 - NUMBERS ALONG THE RIGHT SIDE OF THE SCHEMATIC DESIGNATE THE LOCATION OF CONTACTS BY THE LINE NUMBER, AN UNDERLINED NUMBER INDICATES A NORMALLY CLOSED CONTACT. AN OPEN ARROW BELOW THE LINE NUMBER POINTING UPWARD INDICATES A TIMED CONTACT WHICH BEGINS TIMING WHEN ENERGIZED.
- 4 1KF1 AND 1XP50 ARE LOCATED IN MAIN CONTROL PANEL.

LEGEND		
DEVICE DESIGNATION	DESCRIPTION	LINE NUMBER
3B1	FLAME DETECTOR #1	19
3B2	FLAME DETECTOR #2	18
3E1	IGNITER #1	13
3KF25	CONTROL - 2-STAGE	18
3KF33	MODULE - IGNITION #1	11
3M17	MOTOR - COMBUSTION BLOWER #1	14
3QM20	GAS VALVE #1	8
3QM21	GAS VALVE #2	10
3RF1	FILTER - RFI	1
3S14	SWITCH - SUPPLY AIRFLOW	12
3S15	SWITCH - HIGH TEMP CUTOUT	7
3S16	SWITCH - HIGH PRESSURE #1	9
3S18	SWITCH - FLAME ROLL OUT #1	10
3T6	TRANSFORMER - 24VAC	3

WIRE COLOR ABBREVIATION CODES			
CODE	COLOR	CODE	COLOR
BK	BLACK	PK	PINK
BL	BLUE	R	RED
BR	BROWN	TQ	TURQUOISE
G	GREEN	V	VIOLET
GY	GREY	W	WHITE
O	ORANGE	Y	YELLOW

DESIGNER:	K. EDWARDS
ENGINEER:	R. ROBINSON
TRANE © DATE:	8/14/18
REPLACES:	---
SIMILAR TO:	---
REVISION DATE:	2/06/19
REVISED BY:	K. EDWARDS
APPROVED BY:	R. ROBINSON
CAD SYSTEM USED:	PRO / DIAGRAM

TRANE ®
THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE.
IEC DESIGN COMPLIANT

INTELLIPAK DIAGRAM SCHEMATIC / LAYOUT - STAGED GAS HEAT 500MBH			
MASTER NUMBER:	DRAWING NUMBER:	SHEET:	REV
12132951	12132828	1 OF 1	D