



TRANE®

DATE: 12-18-95

ABSORPTION LIQUID CHILLER

ABDA HORIZON™ TWO-STAGE DIRECT-FIRED ABSORPTION
UNIT SCHEMATIC WIRING DIAGRAM

BURNER CONTROL MODULE AND NATURAL GAS WEISHAUP BURNER VARIATION "C"
ABDA 1200 THRU 1650 UNITS WITH CSD-1, FM, IRI OR NFPA FUEL TRAIN AGENCY APPROVAL

DRAWING NUMBER

2307-8210

REV

E

SHEET 4 OF 6

NOTE:

- SOLID LINES INDICATE WIRING BY THE TRANE COMPANY AND DASHED LINES INDICATE FIELD WIRING PROVIDED BY CUSTOMER. REFER TO UNIT FIELD WIRING LAYOUT AND CONNECTION DIAGRAMS TO DETERMINE THE ACTUAL CUSTOMER SUPPLIED DEVICES AND WIRING REQUIRED ON THE UNIT.
- NUMBERS ALONG THE RIGHT SIDE OF THE SCHEMATIC DESIGNATE THE LOCATION OF DEVICE CONTACTS BY LINE NUMBER. AN UNDERLINED NUMBER INDICATES A NORMALLY CLOSED CONTACT.

