



23 USE CLASS 1 WIRING FOR ALL 115 VAC APPLICATIONS. BINARY INPUTS/ OUTPUTS ASSOCIATED WITH FAN CONTROL ARE 115 VAC.

28 USE CLASS 2 WIRING FOR 24 VDC AND 24 VAC APPLICATIONS. ANALOG/BINARY INPUTS AND ANALOG OUTPUTS ARE 24 VDC. BINARY OUTPUTS ARE 24 VAC.

41 2S18 & 2S19 ARE LOW PRESSURE CUTOFF SWITCHES USED FOR COMPRESSOR PROTECTION (36 PSIG). CAUTION!! DO NOT JUMPER ACROSS SWITCH UNDER ANY CIRCUMSTANCES.

42 STAGING SHOWN WITH LEAD/LAG DISABLED.

43 CONNECTIONS SHOWN ARE FOR SYSTEMS UTILIZING THE TRANE CCRB CONDENSING UNIT.

¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!
LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.
NO SEGUIR LAS INSTRUCCIONES ANTERIORES PUEDE PROVOCAR DAÑOS EN EL EQUIPO.

SHEET
3 OF 5