

DEVICE DESIGNATION	LEGEND DESCRIPTION	LINE NUMBER	DEVICE DESIGNATION	LEGEND DESCRIPTION	LINE NUMBER
1CB1	SUPPLY FAN CIRCUIT BREAKER	17-19, 86	2RT15	SAT. CONDENSER TEMP. CKT.2	139
1CB2	COMPRESSOR CIRCUIT BREAKERS	25-27, 125	2RT18	ENT. WATER TEMP. SENSOR	162
1CB3	COMPRESSOR CIRCUIT BREAKERS	32-34, 137	2S2	HIGH PRESSURE CUTOUT CKT.1	125
1D1	TIME DELAY RELAY	141	2S3	HIGH PRESSURE CUTOUT CKT.2	137
1F4.5	TRANS. PRIMARY FUSE	145	2S6	WATER FLOW SWITCH	159
1F6	TRANS. SECONDARY FUSE	50.51	2S18	LOW PRESSURE CUTOUT CKT.1	125
1F8.9	TRANS. PRIMARY FUSE	52.53	2S19	LOW PRESSURE CUTOUT CKT.2	137
1K1	FAN CONTACTOR	86	2S40	ENT. AIR LOW TEMP. LIMIT	168
1K2	COMPRESSOR CONTACTOR	124	2U5	ECONOMIZER VALVE ACTUATOR	151
1K3	COMPRESSOR CONTACTOR	136	2U4.3	BYPASS VALVE ACTUATOR	155
1K7	FAN RUN REQUEST RELAY	81, 88	3L2	CALIBRATION SOLENOID	210
1K8	VFD START COMMAND RELAY	79	3TB11	ELECTRIC HEATER CONNECTION	40-42
1S1	DISCONNECT SWITCH	5	3TB14	ELECTRIC HEATER CONNECTION	185,186
1S38	115V CONTROL CIRCUIT SWITCH	56	4B1	SUPPLY FAN MOTOR	18
1S39	24V CONTROL CIRCUIT SWITCH	57	4E1	REFRIGERANT SOLENOID VALVE	142
1T1	CONTROL POWER TRANS. (115V)	54	4E2	REFRIGERANT SOLENOID VALVE	143
1T3.4.5	CONTROL POWER TRANS. (24V)	5.55	4RT1	SUPPLY AIR TEMP. SENSOR	91
1T81	LINE VOLTAGE TERMINAL BLOCK	8	4RT4	MIXED AIR TEMP. SENSOR	174
1T82.3	115VAC FACTORY TERMINAL BLOCK		4RT7	EWAP. TEMP. SENSOR CKT.1	123
1T84	24VAC FACTORY TERMINAL BLOCK		4RT8	EWAP. TEMP. SENSOR CKT.2	135
1T85	24VDC FACTORY TERMINAL BLOCK		4RT11	AUX. TEMP. SENSOR	213
1T86	115VAC FIELD TERMINAL BLOCK		4S8	DIRTY FILTER SWITCH	117
1T87.11	24VAC FIELD TERMINAL BLOCK		4S17	RETURN AIR HIGH TEMP. LIMIT	106
1T86.10	24VDC FIELD TERMINAL BLOCK		4S41	ENT. AIR LOW TEMP. LIMIT	204
1T89	115VAC FIELD TERMINAL BLOCK		4S42	SUPPLY AIRFLOW PROVING SWITCH	113
1T812	COMM. FACTORY TERMINAL BLOCK		4S43	HYD. HEAT LEAVE AIR TEMP. LIMIT	198
1T816	200/480V ELECT. HEAT CONNECT	40-42	4U7	INLET GUIDE VANE ACTUATOR	66
1U10	RTM MODULE	111	5RT5	MORNING WARM-UP SENSOR	186,201
1U32	TIME CLOCK	61	5RT19	OUTDOOR AIR TEMP. SENSOR	100
1U33	MULTIPLE CIRCUIT MODULE	121	5RT20	RETURN AIR TEMP. SENSOR	251
1U34	HEAT MODULE	182,196	5S16	SUPPLY AIR HIGH TEMP. LIMIT	106
1U35	GENERIC BAS MODULE	223	5S22	FUSED DISCONNECT SWITCH	2
1U36	COMPARATIVE ENTHALPHY MODULE	242	5S45	PLENUM HIGH STATIC PRESSURE SW	106
1U37	VENTILATION OVERRIDE MODULE	258	5U22	ASE ACTUATOR	65, 71
1U39	INTERPROCESSOR COMM. BRIDGE	279	5U24	ZONE TEMP. SENSOR	78
1U40	VENTILATION CONTROL MODULE	208	5U24	REMOTE PANEL W/ NSB	65
1U41	WATER-SIDE MODULE	149	5U25	REMOTE PANEL	76
1U42	HUMAN INTERFACE MODULE	286	5U26	ZONE RESET TEMP. SENSOR	97
1U43	TRACEY/LOI-1 COMM. INTERFACE	272	5U27	OUTDOOR AIR HUMIDITY SENSOR	104
1U49	PRESSURE TRANSDUCER	93	5U28	REMOTE HUMAN INTERFACE MODULE	291
2B2.3	PRESSURE TRANSDUCER (VOM)	211	5U29	CV ZONE PANEL	76
2B2S10	A & B COMPRESSOR	26,33	5U30	REMOTE ZONE TEMP. SENSOR	88
2B3S11	COMPRESSOR A WINDING T'STAT	125	5U47	RETURN AIR HUMIDITY SENSOR	253
2B3S11	COMPRESSOR B WINDING T'STAT	137	5U50	CO2 SENSOR	214
2RT11	ENT. CONDENSER WATER TEMP.	151	6U13	HYDRONIC HEAT ACTUATOR	198
2RT14	SAT. CONDENSER TEMP. CKT.1	127	8RT21	SAT. CONDENSER TEMP. CKT.1	127
			8RT22	SAT. CONDENSER TEMP. CKT.2	139
			8U44	LOW AMBIENT DAMPER ACTUATOR	133
			8U45	LOW AMBIENT DAMPER ACTUATOR	147
			W11	RUN PERMISSION JUMPER	79, 86
			W12	EMERGENCY STOP JUMPER	106
			W13	SUPP. HIGH TEMP. LIMIT JUMPER	106
			W14	EXTERNAL AUTO/STOP JUMPER	109
			W30	WATER FLOW SWITCH JUMPER	159
			W31	ENT. AIR LOW TEMP. JUMPER	168
			W32	GBAS JUMPER	239
			W39	GEN JUMPER	244

DEVICE DESIGNATION	LEGEND DESCRIPTION	LINE NUMBER
1CB1	SUPPLY FAN CIRCUIT BREAKER	17-19, 86
1CB2	COMPRESSOR CIRCUIT BREAKERS	25-27, 125
1CB3	COMPRESSOR CIRCUIT BREAKERS	32-34, 137
1D1	TIME DELAY RELAY	141
1F4.5	TRANS. PRIMARY FUSE	145
1F6	TRANS. SECONDARY FUSE	50.51
1F8.9	TRANS. PRIMARY FUSE	52.53
1K1	FAN CONTACTOR	86
1K2	COMPRESSOR CONTACTOR	124
1K3	COMPRESSOR CONTACTOR	136
1K7	FAN RUN REQUEST RELAY	81, 88
1K8	VFD START COMMAND RELAY	79
1S1	DISCONNECT SWITCH	5
1S38	115V CONTROL CIRCUIT SWITCH	56
1S39	24V CONTROL CIRCUIT SWITCH	57
1T1	CONTROL POWER TRANS. (115V)	54
1T3.4.5	CONTROL POWER TRANS. (24V)	5.55
1T81	LINE VOLTAGE TERMINAL BLOCK	8
1T82.3	115VAC FACTORY TERMINAL BLOCK	
1T84	24VAC FACTORY TERMINAL BLOCK	
1T85	24VDC FACTORY TERMINAL BLOCK	
1T86	115VAC FIELD TERMINAL BLOCK	
1T87.11	24VAC FIELD TERMINAL BLOCK	
1T86.10	24VDC FIELD TERMINAL BLOCK	
1T89	115VAC FIELD TERMINAL BLOCK	
1T812	COMM. FACTORY TERMINAL BLOCK	
1T816	200/480V ELECT. HEAT CONNECT	40-42
1U10	RTM MODULE	111
1U32	TIME CLOCK	61
1U33	MULTIPLE CIRCUIT MODULE	121
1U34	HEAT MODULE	182,196
1U35	GENERIC BAS MODULE	223
1U36	COMPARATIVE ENTHALPHY MODULE	242
1U37	VENTILATION OVERRIDE MODULE	258
1U39	INTERPROCESSOR COMM. BRIDGE	279
1U40	VENTILATION CONTROL MODULE	208
1U41	WATER-SIDE MODULE	149
1U42	HUMAN INTERFACE MODULE	286
1U43	TRACEY/LOI-1 COMM. INTERFACE	272
1U49	PRESSURE TRANSDUCER	93
2B2.3	PRESSURE TRANSDUCER (VOM)	211
2B2S10	A & B COMPRESSOR	26,33
2B3S11	COMPRESSOR A WINDING T'STAT	125
2B3S11	COMPRESSOR B WINDING T'STAT	137
2RT11	ENT. CONDENSER WATER TEMP.	151
2RT14	SAT. CONDENSER TEMP. CKT.1	127

AREA	LOCATION	DEVICE PREFIX LOCATION CODE
1	UNIT CONTROL PANEL	
2	COMPRESSOR SECTION	
3	ELECTRIC HEATER CONTROL PANEL	
4	SUPPLY FAN & COIL SECTION	
5	FIELD INSTALLED DEVICE	
6	STEAM/HOT WATER HEAT SECTION	
7	INVERTER CONTROL PANEL	
8	REMOTE AIR COOLED COND. SECTION (CCRB)	

