




TRANE THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE CONSENT OF TRANE.		FILE NUMBER:	DRAWING NUMBER: 2307-9114	SHEET: 1 OF 1	REV B
DRAWN BY: T.DEPRIEST	TRANE® DATE: 08/29/08	ROOFTOP PACKAGED AIR CONDITIONER DIAGRAM			
REPLACES: 2307-6603	REVISION DATE: 7-16-09	SCHEMATIC - SINGLE CIRCUIT COMPRESSOR MODULE RT 20-30 TON SHEET 3 OF 5			
CAD SYSTEM USED: ProE/DETAIL	SIMILAR TO: --				

NOTES:

42S4 IS A LOW PRESSURE CUTOUT SWITCH USED FOR COMPRESSOR PROTECTION (25 PSIG). CAUTION!! DO NOT JUMPER ACROSS SWITCH UNDER ANY CIRCUMSTANCES.

42 STAGING SHOWN WITH LEAD/LAG DISABLED.

44 COMPRESSOR STAGE 1 (KNS) & COMPRESSOR STAGE 2 (KNS) AS SHOWN ARE APPLICABLE TO 20 & 30 TON UNITS.
COMPRESSOR STAGE 1 (KNS) & COMPRESSOR STAGE 2 (KNS).

CAUTION

USE COPPER CONDUCTORS ONLY!
UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.
FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

PRECAUCIÓN

N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!
LES TERMINALES DE L'UNITÉ NE SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.
L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'EQUIPEMENT.

ATTENTION

UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!
LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.
SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.