




C	2309-2954	1/1
Date: 01-02-05		REV. /
CAO	Std	

2 TUBI FREDDO

2 BUIZEN KOUD

2 TUBOS ENFRIADOR



ITEM	FRANCAIS	DEUTSCH	ENGLISH
X...	BORNIER UNITE	HAUPTKLEMMLEISTE	UNIT TERMINAL BLOCK
4M40	MOTEUR VENTILATEUR	MOTOR, VENTILATOR	FAN MOTOR
1C46	CONDENSATEUR VENTILATEUR	KONDENSATOR, INNENVENTILATOR	FAN MOTOR CAPACITOR
A1	MODULE DE REGULATION UNITE	ELEKTRONIKMODULE STEUERZENTRALE	UNIT CONTROL MODULE
1F50	FUSIBLE UNITE	SICHERUNG MASCHINE	UNIT FUSE

REPERE	OPTIONS	ZUBEHOER	OPTIONS
① TH11	THERMOSTAT MURAL	RAUM-THERMOSTATSET	WALL THERMOSTAT
② 5R3	SONDE DE REPRISE	RUCKLUFTFUHLER	RETURN AIR SENSOR
③ S2	CONTACT DE FENETRE	FENSTERKONTAKT	WINDOW CONTACT
④ Y1	VANNE D'EAU FROIDE	KALTWASSER VENTIL	COOLING VALVE
⑤ A60	POMPE A CONDENSAT	WASSER PUMP KONDENSATS	CONDENSATE PUMP
⑥ S60	CONTACT DEFALT POMPE A CONDENSAT	VERDICHTUNGSPUMPE	CONDENSATE PUMP FAULT CONTACT
⑦	CÂBLE D'ALIMENTATION GENERALE	HAUPTSTROMKABEL	GENERAL SUPPLY WIRES

———	CABLAGE TRANE	TRANE VERDRAHTUNG	TRANE WIRING
— — —	CABLAGE CLIENT	VERDRAHTUNG DURCH KUNDEN	CUSTOMER WIRING

ITEM	ITALIANO	NEDERLANDS	ESPAÑOL
X...	TERMINALI UNITÀ	UNIT ANNSLUITKLEMMEN BLOCK	TERMINAL UNIDAD
4M40	MOTOR VENTILATORE	VENTILATORMOTOR	MOTOR VENTILADOR
1C46	CONDENSATORE VENTILATORE	START CONDENSATOR VENTILATOR	CONDENSADOR VENTILADOR
A1	MODULO REGOLAZIONE DELL'UNITA	MACHINEREGELMODUUL	MODULO DE REGULACION DE LA UNIDAD
1F50	FUSIBILE UNITA	UNITBEVEILIGING	FUSIBLE UNIDAD

REPERE	OPZIONI	TOEBEHOREN	OPCIONES
① TH11	TERMOSTATO MURALE	MUURTHERMOSTAAT	TERMOSTATO MURAL
② 5R3	SONDA ARIA DI RIPRESA	RETOURLUCHT SENSOR	SONDA DE AIRE DE ROTORNO
③ S2	CONTACTO DE VENTANA	VENSTERCONTACT	SENSORE FINESTRA
④ Y1	VALVOLA ACQUA RAFFREDDAMENTO	KOELKLEP	VALVULA DE AGUA FRIO
⑥ A60	BOMBA CONDENSAD	CONDENSAATPOMP	POMPA A CONDENSA
⑥ S60	CONTACTO DEFECTO BOMBA CONDENSAD	CONTACT DEFECT CONDENSAATPOMP	SENSORE DIFETTO POMPA A CONDENSA
⑦	CAVO DI ALIMENTAZIONE GENERALE	HOOFDVOEDINGSKABELS	CABLE DE ALIMENTACION GENERAL

_____	CABLAGGIO TRANE	DOOR TRANE BEDRAAD	CABLEADO TRANE
____ _	CABLAGGIO CLIENTE	DOOR KLANT BEDRAAD	CABLEADO CLIENTE

Sonde de reprise seule
Ruckluftfuhler

B Return air sensor only
Sonda aria di ripresa soli
Retourlucht sensor alleen
Sonda de aire de retorno solos

TH11	réf.: 35168661-001	+ Sonde de reprise
TH11	réf.: 35168661-001	+ Ruckluftfühler
TH11	réf.: 35168661-001	+ Return air sensor
TH11	réf.: 35168661-001	+ Sonda aria di ripresa
TH11	réf.: 35168661-001	+ Retourlucht sensor
TH11	réf.: 35168661-001	+ Sonda de aire de retorno

Supprimer ce pont pour utilisation de S60
Bei Verwendung von S60 diese brücke entfernen
Remove this jumper when using S60
Eliminare il ponticello se si utilizza S60
Verwijder deze jumper wanneer S60 wordt toegepast
Quitar este puente si se usa S60

CODE COULEUR FARBMARKIERUNG COLOUR CODE		
BK: NOIR	SCHWARZ	BLACK
BN: BRUN	BRAUN	BROWN
BU: BLEU	BLAU	BLUE
GY: GRIS	GRAU	GRAY
RD: ROUGE	ROT	RED
WH: BLANC	WEISS	WHITE
GN: VERT	GRUEN	GREEN
OG: ORANGE	ORANGE	ORANGE
YE: JAUNE	GELB	YELLOW
VE: VIOLET	VIOLETT	PURPLE

	CODICE KLEUR CODIGO	COLORE CODERING COLORES	
BK:	NERO	ZWART	NEGRO
BN:	MARRONE	BRUIN	MARRON
BU:	BLU	BLAUW	AZUL
GY:	GRIGIO	GRIJS	GRIS
RD:	ROSSO	ROOD	ROJO
WH:	BIANCO	WIT	BLANCO
GN:	VERDE	GROEN	VERDE
OG:	ARANCIONE	ORANJE	NARANJA
YE:	GIALLO	GEEL	AMARILLO
VI:	VIOLA	PAARS	VIOLETA

CÂBLAGE UNITE STANDARD STANDARD MASCHINE VERDRAHTUNG UNIT STANDARD WIRING UNITA STANDARD CABLAGGIO STANDAARD MACHINE BEDRADING CABLEADO UNIDAD STANDARD			
	#11	#12	#15
LOW	RD	RD	BN
MEDIUM	YE	BU	GY
HIGH	BK	BK	BK

C	2309-2954	1/1
---	-----------	-----