



TRANE®

HFR SIEMENS

C 2309-2957 1/1

Date: 01-02-05 REV. /

CAO

Std

2 TUBES CHANGE-OVER


2 TUBI CHANGE-OVER

2 ROHRE AUTOMATISCHE UMSCHALTUNG

2 BUIZEN CHANGE-OVER

2 PIPE CHANGE-OVER

2 TUBOS CHANGE-OVER



ITEM	FRANCAIS	DEUTSCH	ENGLISH
X...	BORNIER UNITE	HAUPTKLEMMLEISTE	UNIT TERMINAL BLOCK
4M40	MOTEUR VENTILATEUR	MOTOR, VENTILATOR	FAN MOTOR
1C46	CONDENSATEUR VENTILATEUR	KONDENSATOR, INNENVENTILATOR	FAN MOTOR CAPACITOR
A1	MODULE DE REGULATION UNITE	ELEKTRONIKMODULE STEUERZENTRALE	UNIT CONTROL MODULE
1F50	FUSIBLE UNITE	SICHERUNG MASCHINE	UNIT FUSE
B8	SONDE CHANGE-OVER AUTOMATIQUE	AUTOMAT. UMSCHALTUNG FUEHLER	AUTOMATIC CHANGE-OVER SENSOR

REPERE	OPTIONS	ZUBEHOER	OPTIONS
① TH11	THERMOSTAT MURAL	RAUM-THERMOSTATSET	WALL THERMOSTAT
② SR3	SONDE DE REPRISE	RUCKLUFTFUHLER	RETURN AIR SENSOR
③ S2	CONTACT DE FENETRE	FENSTERKONTAKT	WINDOW CONTACT
④ Y1	VANNE D'EAU FROIDE	KALTWASSER VENTIL	COOLING VALVE
④ Y2	VANNE D'EAU CHAUDE	WARMWASSER VENTIL	HEATING VALVE
⑥ A60	POMPE A CONDENSAT	WASSER PUMP KONDENSATS	CONDENSATE PUMP
⑥ S60	CONTACT DEFAULT POMPE A CONDENSAT	VERDICHTUNGSPUMPE	CONDENSATE PUMP FAULT CONTACT
⑦	CÂBLE D'ALIMENTATION GENERALE	HAUPTSTROMKABEL	GENERAL SUPPLY WIRES

— — —	CABLAGE TRANE	TRANE VERDRAHTUNG	TRANE WIRING
— — —	CABLAGE CLIENT	VERDRAHTUNG DURCH KUNDEN	CUSTOMER WIRING

ITEM	ITALIANO	NEDERLANDS	ESPAÑOL
X...	TERMINALI UNITÀ	UNIT ANNSLUITKLEMMEN BLOCK	TERMINAL UNIDAD
4M40	MOTOR VENTILATORE	VENTILATORMOTOR	MOTOR VENTILADOR
1C46	CONDENSATORE VENTILATORE	START KONDENSATOR VENTILATOR	CONDENSADOR VENTILADOR
A1	MODULO REGOLAZIONE DELL'UNITÀ	MACHINEREGELMODUUL	MODULO DE REGULACION DE LA UNIDAD
1F50	FUSIBILE UNITÀ	UNITBEVEILIGING	FUSIBLE UNIDAD
B8	SONDA DEL SISTEMA DI INVERS. DI CICLO	AUTOMATISCHE CHANGE-OVER SENSOR	SENSOR DE CAMBIO AUTOMATICO

REPERE	OPZIONI	TOEBEHOREN	OPCIONES
① TH11	TERMOSTATO MURALE	MUURTHERMOSTAAT	TERMOSTATO MURAL
② SR3	SONDA ARIA DI RIPRESA	RETOURLUCHT SENSOR	SONDA DE AIRE DE ROTORNO
③ S2	CONTACTO DE VENTANA	VENSTERCONTACT	SENSORE FINESTRA
④ Y1	VALVOLA ACQUA RAFFREDDAMENTO	KOELKLEP	VALVULA DE AGUA FRIO
④ Y2	VALVOLA ACQUA RISCALDAMENTO	VERWARMINGSKLEP	VALVULA DE AGUA CALOR
⑥ A60	BOMBA CONDENSAD	CONDENSAATPOMP	POMPA A CONDENSA
⑥ S60	CONTACTO DEFECTO BOMBA CONDENSAD	CONTACT DEFECT CONDENSAATPOMP	SENSORE DIFETTO POMPA A CONDENSA
⑦	CAVO DI ALIMENTAZIONE GENERALE	HOOFDVOEDINGSKABELS	CABLE DE ALIMENTACION GENERAL

— — —	CABLAGGIO TRANE	DOOR TRANE BEDRAAD	CABLEADO TRANE
— — —	CABLAGGIO CLIENTE	DOOR KLANT BEDRAAD	CABLEADO CLIENTE

TH11 réf.: 35168661-001

Sonde de reprise seule
Ruckluftfuhler

Return air sensor only
Sonda aria di ripresa soli
Retourlucht sensor alleen
Sonda de aire de retorno solos

TH11 réf.: 35168661-001 + Sonde de reprise
TH11 réf.: 35168661-001 + Ruckluftfuhler
TH11 réf.: 35168661-001 + Return air sensor
TH11 réf.: 35168661-001 + Sonda aria di ripresa
TH11 réf.: 35168661-001 + Retourlucht sensor
TH11 réf.: 35168661-001 + Sonda de aire de retorno

Supprimer ce pont pour utilisation de S60

Bei verowendung von S60 diese brucke entfernen

Remove this jumper when using S60

Eliminare il ponticello se si utilizza S60

Verwijder deze jumper wanneer S60 wordt toegepast

Quitar este puente si se usa S60

CODE COULEUR	FARBMARKIERUNG	COLOUR CODE
BK: NOIR	SCHWARZ	BLACK
BN: BRUN	BRAUN	BROWN
BU: BLEU	BLAU	BLUE
GY: GRIS	GRAU	GRAY
RD: ROUGE	ROT	RED
WH: BLANC	WEISS	WHITE
GN: VERT	GRUEN	GREEN
OG: ORANGE	ORANGE	ORANGE
YE: JAUNE	GELB	YELLOW
VT: VIOLET	VIOLETT	PURPLE

CODICE COLORE	KLEURCODERING	CODIGO COLORES
BK: NERO	ZWART	NEGRO
BN: MARRONE	BRUIN	MARRON
BU: BLU	BLAUW	AZUL
GY: GRIGIO	GRIS	GRIS
RD: ROSSO	ROOD	ROJO
WH: BIANCO	WIT	BLANCO
GN: VERDE	GROEN	VERDE
OG: ARANCIONE	ORANJE	NARANJA
YE: GIALLO	GEEL	AMARILLO
VT: VIOLA	PAARS	VIOLETA

CÂBLAGE UNITE STANDARD	STANDARD MASCHINE VERDRAHTUNG	UNIT STANDARD WIRING	UNITA STANDARD CABLAGGIO	STANDAARD MACHINE BEDRADING	CABLEADO UNIDAD STANDARD
	#11	#12	#15		
LOW	RD	RD	BN		
MEDIUM	YE	BU	GY		
HIGH	BK	BK	BK		