



↳ BRT12 IS REQUIRED FOR RAPID RESTART, WHEN UNIT HAS RAPID RESTART OPTION WITHOUT COMPARATIVE ENTHALPY. TIE BACK AND STOW WIRES 595B AND 596B.