
TRANE
THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE CONSENT OF TRANE.
DRAWN BY: D. SHANNON
TRANE® DATE: 4-30-08
REPLACES: 2309-4008
REVISION DATE: 10-29-09
CAD SYSTEM USED: PRO/DETAIL
SIMILAR TO:
FILE NUMBER:
DRAWING NUMBER: 2309-3794
SHEET: 1 OF 1
REV E
ROOFTOP PACKAGED AIR CONDITIONER DIAGRAM
CONNECTIONS - CONTROL BOX
AIR COOLED STANDARD W/LOW AMBIENT 2-PC (120T-150T)
SHEET 1 OF 4
1U3 MULTI-CIRCUIT COMPRESSOR MODULE #1
SEE CONTROL MODULES CONNECTION PRINT FOR DETAILS
1U66 NETWORK COMM. MODULE (BCI)
(SEE MODULES PRINT FOR DETAILS)
1U1 ROOFTOP MODULE (RTM)
SEE CONTROL MODULES CONNECTION PRINT FOR DETAILS
AG/AK/AP/AS/AM
1TB17
1TB18
1T1 460V/60HZ
1T1 575V/60HZ
1T1 380V/50HZ
1F10
1F11
1F12
1F13
1F14
1F15
1K9
1K10
1K11
1K12
CONDENSER FAN CONNECTORS (MOUNTED IN CONTROL BOX WALL)
1P122
1P125
1TB9
1TB10
1TB11
NOTES
1 JUMPER BETWEEN 1TB16-13 AND 1TB16-14 REQUIRED FOR 2-STAGE NATURAL GAS HEAT (<1800 MBH) OR ELECTRIC HEAT ONLY.
2 1TB7 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS 0-5V MODULE ONLY.
3 1TB8 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS 0-10V MODULE ONLY.
4 REMOVE JUMPER BETWEEN 1TB13-23 AND 1TB13-24 WHEN HIGH DUCT TEMP T-STAT (4S17 & 8S17) IS ORDERED.
5 1F25, 1F26, AND 1S8 AND ASSOCIATED WIRING REQUIRED FOR CONVENIENCE OUTLET OPTION ONLY.
6 WIRES W1B, W2B AND W3B ARE ONLY REQUIRED FOR SPECIFIC ELECTRIC HEATER CONFIGURATIONS. SEE APPLICABLE HEATER SCHEMATIC.
7 REMOVE JUMPER BETWEEN 1TB4-15 AND 1TB4-16 WHEN A REMOTE EMERGENCY STOP SWITCH IS USED.
8 1TB29 NOT AVAILABLE WHEN BOTH 0-5V GBAS AND 0-10V GBAS ARE INSTALLED. IF A SINGLE GBAS IS INSTALLED, 1TB29 WILL OCCUPY THE POSITION WHERE THE TERMINAL BLOCK SUPPORTING THE SECOND GBAS WOULD BE PLACED. (SEE INSET 1A)
9 CIRCUIT BREAKERS CB1, CB2, CB3 & CB4 MUST CONNECT TO COLORED AUX CONTACT WIRES BLU/YEL (COM) AND YEL (NO) WHEN SHORT CIRCUIT WITHSTAND RATING (SCWR) IS CHOSEN AS AN OPTION.
10 FOR RETURN FAN INSTALL JUMPER BETWEEN 1TB13-11 & 1TB13-12. FOR EXHAUST FAN PROVING INSTALL WIRES 548C AND 549C.
1U2 (HUMAN INTERFACE)
NOTE: CONNECTIONS SHOWN FROM VIEWING BACK OF 1U2
FUSE AND SWITCH PANEL
MARINE LIGHTS
OPTIONAL CONVENIENCE OUTLET
OPTIONAL ELECTRIC HEAT
OPTIONAL EXHAUST/RTN FAN
OPTIONAL ENERGY WHEEL
INLET GUIDE VANE
S/A DUCT PRESSURE
ECONOMIZER
EXHAUST DAMPER
R/A SPACE PRESSURE
R/A PLENUM PRESSURE (RTN FAN ONLY)
ENERGY RECOVERY (EXHAUST FAN ONLY)
SEE CONTROL MODULES CONNECTION PRINT FOR DETAILS
1U5 EXHAUST/COMPARATIVE ENTHALPY MODULE (ECEM)
1U6 HEAT MODULE (HEAT)
1U7 LONTALK COMMUNICATIONS MODULE (LCI)
1U8 VENTILATION OVERRIDE MODULE (VOM)
1U9 MULTI-PURPOSE MODULE (MPM)
1U10 GBAS 0-5V MODULE
1U11 GBAS 0-10V MODULE
1U12 INTERPROCESSOR COMMUNICATIONS MODULE (IPCB)
1U15 MODULATING DEHUMIDIFICATION MODULE (MDM)
ENERGY WHEEL ONLY
OPT. MARINE LIGHTS
120 VAC/60HZ
INSET 1A - CUSTOMER CONNECTION TB CONFIGS
W/O GBAS 0-5V, GBAS 0-10V, AND ERW
W/ ENERGY RECOVERY (ERW)
W/ GBAS 0-5V AND ERW
W/ GBAS 0-10V AND ERW
W/ GBAS 0-5V AND GBAS 0-10V
GBAS 0-5V ONLY
GBAS 0-10V ONLY
ENERGY RECOVERY