

- NOTES:
- 1 ALL UNITS SHIP WITH AN OPTIONS HARNESS ROUTED FROM THE CONTROL BOX TO THE RETURN AIR SECTION. DO NOT CONNECT THE OPTIONS HARNESS PPFS TO THE RTM IF NO OPTIONS ARE INSTALLED. DO NOT CONNECT OPTIONS HARNESS PPM6 TO THE RTM IF NO ECA IS INSTALLED. REFER TO ACCOMPANYING LITERATURE FOR CONNECTION / COMBINATION OF OPTIONAL COMPONENTS.
 - 2 INSTALL OPTIONAL REMOTE SENSOR TO TERMINALS S1 AND S2 WHEN REQUIRED. SEE PROGRAMMABLE ZONE SENSOR / REMOTE PANEL W/ NSB LITERATURE FOR OPTION CONFIGURATION.

- | | |
|----|--|
| 17 | TERMINALS 7,8,9 AND 10 ARE FOR OPTIONAL INDICATORS. |
| 18 | WIRE AS SHOWN WHEN OPTIONAL REMOTE MINIMUM POSITION POTENTIOMETER IS REQUIRED. |
| 19 | INSET E IS FOR OPTIONAL PROGRAMMABLE ZONE SENSOR. |
| 20 | REQUIRED FOR OPTIONAL REFERENCE ENTHALPY CONTROL. |
| 21 | REQUIRED FOR OPTIONAL COMPARATIVE ENTHALPY CONTROL. |
| 25 | 0-10 VDC DUCT MOUNTED SENSOR ONLY. |
| 26 | OPTIONAL MAS, RAS, RHS, OHS AND ASSOCIATED WIRING NOT USED WITH MOTORIZED OUTSIDE AIR. |
| 28 | AUXILIARY RELAY ENERGIZED DURING OCCUPIED PERIODS. |

- | | |
|----|---|
| 29 | TO DISABLE COMPRESSORS, REMOVE JUMPERS AND CONNECT FIELD SUPPLIED CONTROL DEVICE. |
| 30 | TO SHUT DOWN THE UNIT FOR EMERGENCY STOP, REMOVE JUMPER AND INSTALL FIELD SUPPLIED DEVICE. |
| 32 | POWER EXHAUST OUTPUT FOR FIELD SUPPLIED DEVICE. |
| 33 | TO ENABLE COMPRESSOR LEAD/LAG OPERATION, CUT WIRE 36B. |
| 35 | CONNECT WIRES 36B9 AND 36BZ TO ENABLE 3 STAGE COOLING ONLY ON HIGH EFFICIENCY SHORT ORIFICE UNITS. |
| 36 | FAN CONTACTOR (F) IS NOT USED WITH TITLE 24 OR SINGLE ZONE VAV OPTS. SEE VFD SCHEMATIC FOR TITLE 24/SINGLE ZONE VAV VFDs. |

THIS DRAWING IS PROPERTY OF AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE CONSENT OF TADCO.		FILE NUMBER: 2309-3109		DRAWING NUMBER: 2313-0066		SHEET: 1 OF 1		REV	
DRAWN BY: S. SERTS		TRASH DATE:		VDWAGER 2		DIAGRAM		CONTROL. RELATE. 200, 208-575 VAC 15, 181, 241 DEMONSTRIFICATION	
REVISIONS:		REVISION DATE: 10-6-11		2		2		2	
CAD SYSTEM USED:		SIMULATED TO:		2309-3662		2309-3662		2309-3662	
PROJ DETAIL		2309-3662		2309-3662		2309-3662		2309-3662	