


TRANE THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE CONSENT OF TRANE.		FILE NUMBER: --	DRAWING NUMBER: 2313-0452	SHEET: 1 OF 1	REV B
DRAWN BY: B.WALDEN		TRANE DATE: 27-Jun-11			
REPLACES: --		REVISION DATE: 9 DEC 2014			
CAD SYSTEM USED: Pro/DETAIL		SIMILAR TO: --			
ODYSSEY CONNECTION AIR HANDLER - 2-SPEED ELECTROMECHANICAL --					

SHEET SIZE: 8.5 X 11 INCHES




NOTES:

- SEE FIELD WIRING DIAGRAMS IN PRODUCT LITERATURE FOR PROPER FIELD CONNECTIONS.
- REMOVE JUMPER WIRE 71J (BK) TO ALLOW TWO STAGES OF ELECTRIC HEAT.
- WIRES 27B, 29B, 35P, AND 37T ARE USED FOR OPTIONAL TRANSFORMER KIT - CONNECTING AIR HANDLER UNIT WITH TWO RESIDENTIAL CONDENSER UNITS.
- CONNECTIONS SHOWN ARE FOR 230V/575V MODELS. FOR 208V/400V/460V, WIRE 27B(R) IS CONNECTED TO THE APPROPRIATE TERMINAL ON THE TRANSFORMER.

WIRE COLOR DESIGNATION			
ABBR	COLOR	ABBR	COLOR
BL	BLUE	O	ORANGE
BK	BLACK	R	RED
BR	BROWN	V	VIOLET (PURPLE)
G	GREEN	W	WHITE
GY	GRAY (SLATE)	Y	YELLOW



30A.B.C(G)



CAUTION

USE COPPER CONDUCTORS ONLY!

UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.

FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

PRECAUCIÓN

N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!

LES BORNES DE L'UNITÉ NE SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.

L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.

ATTENTION

¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!

LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.

SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.