

CAUTION

USE COPPER CONDUCTORS ONLY!

UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.

FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

ATTENTION

N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!

LES BORNES DE L'UNITÉ NE SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.

L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.

PRECAUCIÓN

¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!

LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.

SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.

LEGEND

DEVICE DESIG	DESCRIPTION	LINE NUMBER
AH	CONTACTOR - ELECTRIC HEAT	68.69.70.101
BH	CONTACTOR - ELECTRIC HEAT	76.77.78.100.102
CH	CONTACTOR - ELECTRIC HEAT	84.85.86.103
FU11	FUSE - ELECTRIC HEAT	68
FU12	FUSE - ELECTRIC HEAT	69
FU13	FUSE - ELECTRIC HEAT	70
FU14	FUSE - ELECTRIC HEAT	76
FU15	FUSE - ELECTRIC HEAT	77
FU16	FUSE - ELECTRIC HEAT	78
FU17	FUSE - ELECTRIC HEAT	84
FU18	FUSE - ELECTRIC HEAT	85
FU19	FUSE - ELECTRIC HEAT	86
HLC1	HIGH LIMIT CUTOUT #1	98
HLC2	HIGH LIMIT CUTOUT #2	98
HTRA	HEATER BANK A	68
HTRB	HEATER BANK B	71.76
HTRC	HEATER BANK C	76.79.84
HTRD	HEATER BANK D	79
HTRE	HEATER BANK E	84
HTRF	HEATER BANK F	87
ODF34	OUTDOOR FAN RELAY	98
RTRM	REFRIGERATION MODULE	98
TNS1	CONTROLS POWER TRANSFORMER	94

TRANE
THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE CONSENT OF TRANE.

DRAWN BY: K. EDWARDS
TRANE® DATE: 8/10/09
REPLACES: 2313-0185
REVISION DATE: --
CAD SYSTEM USED: PRO/DIAGRAM
SIMILAR TO: --

FILE NUMBER: 2313-0602
DRAWING NUMBER: 2313-0609
SHEET: 1 OF 1
REV: A

VOYAGER 3
DIAGRAM
HEAT POWER AND CONTROLS SCHEMATIC
72KW/90KW/108KW ELECTRIC HEAT
380V-575V