



- NOTES
- JUMPER BETWEEN 11B16-13 AND 11B16-14 REQUIRED FOR 2-STAGE NATURAL GAS HEAT (<1800 MBH) OR ELECTRIC HEAT ONLY.
 - 11B7 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS 0-5V MODULE ONLY.
 - 11B8 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS 0-10V MODULE ONLY.
 - REMOVE JUMPER BETWEEN 11B13-23 AND 11B13-24 WHEN HIGH DUCT TEMP 1-STAT (4S17 & 8S17) IS ORDERED.
 - 1F25, 1F26, AND 1S8 AND ASSOCIATED WIRING REQUIRED FOR CONVENIENCE OUTLET OPTION ONLY.
 - WIRES 1AB, 2AB AND 3AB ARE ONLY REQUIRED FOR SPECIFIC ELECTRIC HEATER CONFIGURATIONS. SEE APPLICABLE HEATER SCHEMATIC.
 - REMOVE JUMPER BETWEEN 11B4-15 AND 11B4-16 WHEN A REMOTE EMERGENCY STOP SWITCH IS USED.
 - 11B29 NOT AVAILABLE WHEN BOTH 0-5V GBAS AND 0-10V GBAS ARE INSTALLED. IF A SINGLE GBAS IS INSTALLED, 11B29 WILL OCCUPY THE POSITION WHERE THE TERMINAL BLOCK SUPPORTING THE SECOND GBAS WOULD BE PLACED. (SEE INSET 1A)
 - CIRCUIT BREAKERS CB1, CB2, CB3 & CB4 MUST CONNECT TO COLORED AUX CONTACT WIRES BLU/YEL (COM) AND YEL (NO) WHEN SHORT CIRCUIT WITHSTANDING RATING (SCWR) IS CHOSEN AS AN OPTION.
 - 1S5 (V.F.D. BYPASS SWITCH) AND ASSOCIATED WIRING AVAILABLE ONLY ON UNITS WITH EXHAUST/RETURN VFD WITH BYPASS.
 - FOR RETURN FAN INSTALL JUMPER BETWEEN 11B13-11 & 11B13-12. FOR EXHAUST FAN PROVING INSTALL WIRES 548B AND 549B.

