



- NOTES:
- 460V/60HZ TRANSFORMER SHOWN. SEE DETAIL "1B" FOR 575V/60HZ VOLTAGE CONNECTIONS.
  - JUMPER (1T8-5 & 1T88-6) REQUIRED ONLY ON UNITS WITH 2-STAGE NATURAL GAS HEAT OR ELECTRIC HEAT OPTION.
  - 1T87 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS (1U51).
  - REMOVE JUMPER WHEN HIGH DUCT TEMP T-STAT (3516 - 3517) IS ORDERED.
  - JUMPER INSTALLED ONLY ON UNITS WITHOUT ECONOMIZER OPTION.
  - 1F55, 1F56, 1S74 AND ASSOCIATED WIRING USED ON CONVENIENCE OUTLET OPTION ONLY.
  - MANUAL BYPASS SWITCH AND ASSOCIATED WIRING OPTIONAL.

<p>THIS DRAWING IS THE PROPERTY OF TRANE. IT IS TO BE USED ONLY FOR THE PARTS AND EQUIPMENT SPECIFICALLY IDENTIFIED HEREIN. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.</p> <p>DATE: 2/13/11          DRAWN BY: EDW/ADDS          PROJECT: 2313-114.3          Pkg/DETAIL</p> <p>TRANE          2313-114.3          ROOFTOP PACKAGED AIR CONDITIONER          DIAGRAM          CONNECTION - CONTROL BOX AREA 1          W/ EXHAUST FAN VARIABLE FREQUENCY DRIVE          90-130 TON - SHEET 1 OF 3</p>	<p>FILE NUMBER: 2313-114.3          DRAWING NUMBER: 2313-114.6          SHEET: 1 OF 1          REV: A</p>
--	---