




LEGEND		
DEVICE DESIG	DESCRIPTION	LINE NUMBER
1C82	CIRCUIT BREAKER - EXHAUST FAN	98
1K17	CONTACTOR - EXHAUST FAN	68,98
1S72	SWITCH - SUPPLY V.F.D. BYPASS	83,87
1U126	OVERLOAD-EXHAUST-FAN	98
1U48	MODULE - RTM	61
1U77	KEYPAD - SUPPLY V.F.D.	77
1U78	KEYPAD - SUPPLY V.F.D.	90
3RT3	SENSOR - OD AIR TEMP	102
3RT9	SENSOR - SUPPLIED AIR TEMP	89
3S16	T-STAT - R/A HIGH DUCT TEMP	108
3S17	T-STAT - S/A HIGH DUCT TEMP	109
3S21	SWITCH - CLOGGED FILTER	93
3S68	SWITCH - S/A PROVING	91
3S69	SWITCH - EXHAUST AIR PROVING	95
3S85	SWITCH - CLOGGED FINAL FILTER	72
3U13	ACTUATOR - ECONOMIZER	65
3U60	TRANSDUCER - S/A DUCT PRESSURE	98
3U63	SENSOR - OD AIR HUMIDITY	104
3U72	SUPPLY V.F.D. ASSEMBLY #1	77
3U73	SUPPLY V.F.D. ASSEMBLY #2	86
5K86	RELAY - OCCUPIED/UNOCCUPIED	119
5K87	RELAY - VAV CHANGEOVER	64
5S67	SWITCH - EXTERNAL AUTO/STOP	116
5S71	SWITCH - EMERGENCY STOP	108
5U108	SENSOR - SPACE RELATIVE HUMIDITY	104
5U56	PANEL - CV REMOTE	77
5U57	SENSOR - ZONE TEMP	65
5U58	PANEL - REMOTE W/ NIGHT SETBACK	83
5U59	PANEL - VAV REMOTE	70
5U61	SENSOR - ZONE RESET TEMP	74
5U68	PANEL - CV ZONE	66
5U69	SENSOR - REMOTE ZONE TEMP	84
5U70	POTENTIOMETER - REMOTE MIN POS	101

TRANS
2313-1833
2313-1835
1 OF 1
B

ROOF TOP PACKAGED AIR CONDITIONER
DIAGRAM
CONTROLS - ROOF TOP MODULE - 90-100 TON
W/ SUPPLY FAN VARIABLE FREQUENCY DRIVE
SCHEMATIC 2 OF 5

DRAWING NUMBER
2313-1835
SHEET
1 OF 1
REV
B