



- NOTES:**
- 460V/60HZ TRANSFORMER SHOWN. SEE DETAIL "1B" FOR 575V/60HZ VOLTAGE CONNECTIONS.
 - JUMPER (1TB8-5 & 1TB8-6) REQUIRED ONLY ON UNITS WITH 2-STAGE NATURAL GAS HEAT OR ELECTRIC HEAT OPTION.
 - 1TB17 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS (1U51).
 - REMOVE JUMPER WHEN HIGH DUCT TEMP T-STAT (3516 - 3517) IS ORDERED.
 - JUMPER INSTALLED ONLY ON UNITS WITHOUT ECONOMIZER OPTION.
 - 1F55, 1F56, 1S74 AND ASSOCIATED WIRING USED ON CONVENIENCE OUTLET OPTION ONLY.
 - ON 1TB10-8 USE WIRE 572E ON 100% EXHAUST UNITS W/O STATITRAC. USE 572F ON 100% EXHAUST UNITS W/ STATITRAC.
 - ON 1K17 AUX SW ITCH USE WIRES 573C & 576A ON UNITS WITH 100% EXHAUST W/O STATITRAC ONLY.
- TRANE**
 DRAWN BY: EDW/ANDS
 PROJECT: 2313-1114A
 CHECKED BY: BRYAN/DAVE
 DATE: 02/27/13
 SHEET NO: 1 OF 3
- FILE NUMBER:** 2313-1892
DRAWING NUMBER: 2313-1893
REVISION: 1 OF 1
TITLE: ROOFTOP PACKAGED AIR CONDITIONER CONNECTION - CONTROL BOX AREA 1 STANDARD SHEET 1 OF 3