

NOTES:

1. 460V/60HZ TRANSFORMER SHOWN. SEE DETAIL "1B" FOR 575/60HZ VOLTAGE CONNECTIONS.
2. JUMPER (1TB8-5 & 1TB8-6) REQUIRED ONLY ON UNITS WITH 2-STAGE NATURAL GAS HEAT OR ELECTRIC HEAT OPTION.
6. 1TB17 AND ASSOCIATED WIRING REQUIRED WITH OPTIONAL GBAS (1U51).
7. REMOVE JUMPER WHEN HIGH DUCT TEMP T-STAT (3S16 - 3S17) IS ORDERED.
9. JUMPER INSTALLED ONLY ON UNITS WITHOUT ECONOMIZER OPTION.
10. 1F55, 1F56 ,1S74 AND ASSOCIATED WIRING USED ON CONVENIENCE OUTLET OPTION ONLY.
11. MANUAL BYPASS SWITCH AND ASSOCIATED WIRING OPTIONAL.

THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE CONSENT OF TRANE

TRANE

DRAWN BY: K. EDWARDS
REPLACES: 2313-1146A
CAD SYSTEM USED: Pro/DETAIL
TRANE® DATE: 5/24/13
SIMILAR TO: --
REVISION DATE: --

FILE NUMBER: 2313-1892
DRAWING NUMBER: 2313-1895
SHEET: 1 OF 1
REV: A

ROOFTOP PACKAGED AIR CONDITIONER DIAGRAM
CONNECTION - CONTROL BOX AREA 1
W/ EXHAUST FAN VARIABLE FREQUENCY DRIVE
90-130 TON - SHEET 1 OF 3