

NOTES:

- 1 ALL WIRING AND DEVICES SHOWN DASHED TO BE SUPPLIED AND INSTALLED BY THE CUSTOMER IN ACCORDANCE WITH LOCAL AND NATIONAL ELECTRICAL CODES.
- 2 IF ANY OF THE ORIGINAL WIRE, AS SUPPLIED WITH THIS UNIT, MUST BE REPLACED, REPLACE IT WITH APPLIANCE WIRING MATERIAL RATED AT 105°C AND 600V.
- 3 THREE PHASE MOTORS ARE PROTECTED UNDER PRIMARY SINGLE PHASING CONDITIONS. ALL MOTORS HAVE INTERNAL OVERLOAD PROTECTION. COMPRESSORS HAVE INTERNAL THERMAL PROTECTION.
- 4 REQUIRED FOR OPTIONAL REFERENCE ENTHALPY CONTROL.
- 5 REQUIRED FOR OPTIONAL COMPARATIVE ENTHALPY CONTROL.
- 6 OPTIONAL MAS, RAS, RHS, OHS AND ASSOCIATED WIRING NOT USED WITH MOTORIZED OUTSIDE AIR.
- 7 WHEN ELECTRIC HEAT OPTION IS REQUIRED, REFER TO ELECTRIC HEAT DIAGRAM FOR CUSTOMER CONNECTIONS.

WIRE COLOR DESIGNATION		IMPORTANT		TRANE		FILE NUMBER:		DRAWING NUMBER:		SHEET:	
ABBR	COLOR	ABBR	COLOR	DO NOT ENERGIZE UNIT UNTIL CHECK-OUT AND START-UP PROCEDURE HAS BEEN COMPLETED.	DRAWN BY:	TRANED DATE:	2313-2018	2313-2019	1 OF 1	REV: B	
BK	BLACK	V (PR)	PURPLE	THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO THIRD PARTIES WITHOUT THE CONSENT OF TRANE.	R. JOHNSON	31-JAN-13					
BL	BLUE	R	RED	REPLACES: 2313-2019A		REVISION DATE: 10-APR-13					
BR	BROWN	TN	TAN	CAD SYSTEM USED: Pro/DETAIL		SIMILAR TO: --					
G	GREEN	W	WHITE								
O	ORANGE	Y	YELLOW								

CAUTION
USE COPPER CONDUCTORS ONLY!

PRECAUCIÓN
N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!

ATTENTION
UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!

UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.

LES BORNES DE L'UNITÉ NE SONT PAS CONçUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.

FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.

SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.

INDOOR SECTION

HEAT SECTION

OUTDOOR SECTION