
TRANE
THIS DRAWING IS PROPRIETARY AND SHALL NOT BE COPIED OR ITS CONTENTS DISCLOSED TO OUTSIDE PARTIES WITHOUT THE WRITTEN CONSENT OF TRANE
© TRANE
DRAWN BY: D. SHANNON
DATE: 16-AUG-13
DO NOT SCALE PRINT
THIRD ANGLE PROJECTION
4366-8507
REV A
DIAGRAM
CONNECTION PRINT
TZC(048,060)E4
ULTRA HIGH EFFICIENCY VSC
CAUTION
USE COPPER CONDUCTORS ONLY!
UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.
FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.
ATTENTION
N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!
LES BORNES DE L'UNITÉ NE SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.
L'UTILISATION DE TOUT AUTRE CONDUCTEUR PEUT ENDOMMAGER L'ÉQUIPEMENT.
PRECAUCIÓN
¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!
LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.
SI NO LO HACE, PUEDE OCASIONAR DAÑO AL EQUIPO.
CONTROL BOX - VERTICAL
DACR
RTOM
VSM
PPF-VSM PPM-VSM
PPF-CONFIG PPM-CONFIG
TONNAGE CONFIGURATION
4T = 100BU(RD) PIN 2
5T = 100BW(RD) PIN 3
CCHR
RTRM
COMM
TB-COM
SUPPLY AIR SECTION
CVD
PFC
DTS
MAS
IDM
COF
FFS
SASD
COF ADAPTER PPM-A PPF-A
CONTROL BOX - HORIZONTAL
NLTB
TNS1
LTB1
RETURN AIR SECTION
PPF-RASD
PPF-PLSD
RASD
OHS
ECA
CFS
FOS
RAS
RHS
HEATER SECTION
PPM-HEAT PPF-HEAT
OUTDOOR SECTION
ODM
CPR1
CCH1
LPC1
HPC1
TDL1
OAS
TNS3
PHM
COVR
CC1
CUSTOMER CONNECTION
RELATIVE HUMIDITY SENSOR
SEE NAMEPLATE FOR LINE VOLTAGE AND MAX FUSE SIZE
ZONE SENSOR
PROGRAMMABLE ZONE SENSOR W/ NIGHT SETBACK
OPTIONAL REMOTE SENSOR
THERMOSTAT