

Declaration of Conformity

Manufacturer's Name: Trane Company
Manufacturer's Address: 4833 White Bear Parkway
St. Paul MN 55110
USA

The manufacturer hereby declares that the product

Product Name: Summit Building Control Unit
Model Number: BMTW000CAOA

Conforms to the following standards or other normative documents:

Electromagnetic Emission: EN50081-1:1992
(by Council Directive 89/336/EEC) Radiated EN55022: 1994 Class B limit
Conducted EN55022: 1994 Class B limit

Electromagnetic Immunity: EN50082-2:1995
(by Council Directive 89/336/EEC) IEC 1000-4-2:1995 ±4.0 kV by contact
EN61000-4-2
IEC 1000-4-3:1995 10.0 V/m
EN61000-4-3 80 .. 1000 MHz
IEC 1000-4-4:1995 ±1.0 kV signal lines
EN61000-4-4 ±2.0 kV ac power lines
IEC 1000-4-6:1996 10 V
EN61000-4-6 0.15 .. 80 MHz
IEC 1000-4-8:1993 30 A/m
EN61000-4-8

Electrical Safety: EN61010-1:1993
(by Council Directive 73/23/EEC) Amendment 2:1995

When and Where Issued

Electromagnetic Emission 09/05/96
Electromagnetic Immunity 07/22/94
Electrical Safety 08/19/99
St. Paul Minnesota USA



John Olson
Design/Compliance Engineer

Mark of Compliance



European Contact

Societe Trane (Epinal, France)
1, rue des Ameriques, B.P. 6
F-88191 Golbey Cedex, France
Phone: 33-329-31-7300
Fax: 33-329-81-2498

This document validates CE conformity of the European Summit BCU.

32703311
Rev 2