

Declaration of Conformity

Manufacturer's Name: Trane
Manufacturer's Address 4833 White Bear Parkway
Saint Paul, Minnesota 55110
USA

The manufacturer hereby declares that the product

Product Name: VariTrac CCP termination/relay module
Product Number: S3090-0336-62
This Module is part of: Varitrac CCP Controller (49500488, 49500489)

Varitrac CCP controller conforms to the following standards or other normative documents:

Electromagnetic Emission: EN 50081-1:1998
(by Council Directive 89/336/EEC) Radiated EN55022: 1998 Class B limit
Conducted EN55022:1998 Class B limit

Electromagnetic Immunity: EN61326-1:1997 +A1 : 1998

EN61000-4-2 ±4 kV contact discharge
±8 kV air discharge

EN61000-4-3 3 V/m

EN61000-4-4 ±1 kV

EN61000-4-5 ±1 kV line-line
±2 kV line-ground

EN61000-4-6 3 V

EN61000-4-8 30 A/m

EN61000-4-11 1 cycle/ 100%

When and where issued:

Electromagnetic Emission : 9/14/2001
Electromagnetic Immunity: 1/4/2001
Saint Paul, Minnesota USA



Bounheng Saycocie
Design/Compliance Engineer

Mark of Compliance

CE

European Contact
Societe Trane (Epinal, France)
1, rue des Ameriques, B.P.6
F-88191 Golby Cedex, France
Phone: (33) 329-31.73.00

This document validates CE conformity of the VariTrac CCP terminator/relay module.

3270 3365
Rev 1